



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2001839
Permit #: 00344-2025CAT
Request Rec'd: 03/24/2025
Approval Date: 03/24/2025 DS
Permit Expires: 09/24/2025

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|---|---|
| OWNER OF TANKS - Corporation, partnership, or other business entity: Cook-Illinois Corp. 2100 Clearwater Drive Oak Brook, IL 60523 Du Page County Contact: Todd Mancuso 708/560-9840 | FACILITY - name and address where tanks are located: Kickert School Bus Line, Inc. 20575 Torrence Avenue Lynwood, IL 60411 Cook County Contact: Alex Sustek 708/758-4740 |
|---|---|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 5 | Gasoline - Regular | 12,000 | Currently in use | Federal |
| 6 | Diesel Fuel | 12,000 | Currently in use | Federal |

Tank 5 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------------|----------------------------------|--------|
| Corrosion Protection - Piping | Sacrificial Anode Flex Connector | New |

Tank 6 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------------|----------------------------------|--------|
| Corrosion Protection - Piping | Sacrificial Anode Flex Connector | New |

NACE Certified Designer
NACE Certified Designer Number
Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work

Install Cathodic Protection on all exposed steel (both tanktop sumps) per NOV Number E0020250226

| | |
|---|--|
| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
| Protanic, LLC 658 North Progress Drive PO Box 80265 Saukville, WI 53080 | Contact Person: Kylie Krombach Phone: 262/268-1150 Email: emilya@protanicinc.com Contractor License # IL1413 Exp. 9/26/2026 |

Sincerely,

Daniel J. Starks

Daniel Starks