



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov  
**Amended**

**FOR OFFICE USE ONLY**  
Facility #: 4015557  
Permit #: 00354-2025UPG  
Request Rec'd: 03/25/2025  
Approval Date: 03/26/2025 DS  
Amended Date: 03/26/2025 DS  
Permit Expires: 09/26/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for  
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Pontiac 66, LLC 212 S. Mill Street Pontiac, IL 61764 (None) County Contact: Sweety Patel 312/860-5502	<b>FACILITY</b> - name and address where tanks are located: Pontiac Citgo 212 S. Mill Street Pontiac, IL 61764 Livingston County Contact: Vrutika Patel 312/860-5502
---	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Diesel Fuel	8,000	Currently in use	Federal
6	Gasoline - Premium	10,000	Currently in use	Federal

**Tank 5 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection

**Tank 6 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Mechanical Pressurized Line Leak Detection

**Summary of Work**

The premium ELLD will be changed to MLLD.

**Special Contingencies**

**Amendment Reason:**

Diesel line ELLD has also failed and a MLLD will be installed.

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: Ed Angell Phone: 708/474-3344 Email: ed.angell@bkequip.com Contractor License # IL1207 Exp. 2/14/2026

Sincerely,

*Daniel J. Starks*

Daniel Starks