



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 5028708  
Permit #: 00364-2025UPG  
Request Rec'd: 03/28/2025  
Approval Date: 03/31/2025 DS  
Permit Expires: 09/30/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for  
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

|                                                                                                                                                                                                        |                                                                                                                                                                                                             |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|
| <b>OWNER OF TANKS</b><br>- Corporation, partnership, or other business entity:<br>Casey's Retail Company<br>3305 SE Delaware Ave. P.O. Box 3004<br>Ankeny, IA 50021<br>Contact: Lee Lytle 515/446-6231 | <b>FACILITY</b><br>- name and address where tanks are located:<br>Casey's General Store #1580<br>221 West State Street<br>Nokomis, IL 62075<br>Montgomery County<br>Contact: Jill Reams-Widder 515/965-6238 |
|--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|

**Tanks on the Permit**

| Tank # | Product            | Capacity | Tank Status      | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 4      | Gasoline - Regular | 22,000   | Currently in use | Federal          |
| 5      | B-11               | 14,000   | Currently in use | Federal          |
| 6      | E15                | 8,000    | Currently in use | Federal          |
| 7      | Gasoline - Premium | 8,000    | Currently in use | Federal          |
| 8      | Gasoline - Premium | 8,000    | Currently in use | Federal          |

**Tank 4 Equipment**

| Equipment Type        | Permit Equipment                                          | Action                                                                                     |
|-----------------------|-----------------------------------------------------------|--------------------------------------------------------------------------------------------|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 Plus with CSLD |

**Tank 5 Equipment**

| Equipment Type        | Permit Equipment                                          | Action                                                                                     |
|-----------------------|-----------------------------------------------------------|--------------------------------------------------------------------------------------------|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 Plus with CSLD |

**Tank 6 Equipment**

| Equipment Type        | Permit Equipment                                          | Action                                                                                     |
|-----------------------|-----------------------------------------------------------|--------------------------------------------------------------------------------------------|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 Plus with CSLD |

### Tank 7 Equipment

| Equipment Type        | Permit Equipment                                          | Action                                                                                     |
|-----------------------|-----------------------------------------------------------|--------------------------------------------------------------------------------------------|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 Plus with CSLD |

### Tank 8 Equipment

| Equipment Type        | Permit Equipment                                          | Action                                                                                     |
|-----------------------|-----------------------------------------------------------|--------------------------------------------------------------------------------------------|
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 Plus with CSLD |

### Summary of Work

Replace existing TLS-350 with TLS-450 Plus

Re-use existing tank probes and floats

### Special Contingencies

#### PERSON, FIRM OR COMPANY PERFORMING WORK:

Neumayer Equipment Company, Inc.  
5060 Arsenal Street  
St. Louis, MO 63139

Contact Person: Jimmy Spiros  
Phone: 314/772-4501  
Email: testing@neumayerequipment.com  
Contractor License # IL1502 Exp. 3/26/2026

Sincerely,



Daniel Starks