

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety 1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

 FOR OFFICE USE ONLY

 Facility #:
 4005008

 Permit #:
 00371-2025UPG

 Request Rec'd:
 03/28/2025

 Approval Date:03/31/2025 DS
 Permit Expires:

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| OWNER OF TANKS - Corporation, partnership, or other business entity: Casey's Retail Company 3305 SE Delaware Ave. P.O. Box 3004 Ankeny, IA 50021 | FACILITY - name and address where tanks are located: Casey's General Store #1401 1603 E. Washington Street Clinton, IL 61727 Dewitt County |
|--|---|
| Contact: Lee Lytle 515/446-6231 | Contact: Teresa Barnes 515/965-6238 |

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 1 | B-11 | 6,000 | Currently in use | Federal |
| 2 | Gasoline - Regular | 10,000 | Currently in use | Federal |

Tank 1 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------|------------------|---|
| | | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD |

Tank 2 Equipment

| Equipment Type | Permit Equipment | Action |
|--------------------------|------------------|--|
| Leak Detection - Tank | | Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350 with CSLD |

Summary of Work

Replace existing TLS-350 with TLS-450 Plus Re-use existing tank probes and floats

Special Contingencies

| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
|--|---|
| Neumayer Equipment Company, Inc. 5060 Arsenal Street St. Louis, MO 63139 | Contact Person: Jimmy Spiros Phone: 314/772-4501 Email: testing@neumayerequipment.com Contractor License # IL1502 Exp. 3/26/2026 |

Sincerely, Daniel J. Starks

Daniel Starks