



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2020407  
Permit #: 00395-2025UPG  
Request Rec'd: 04/01/2025  
Approval Date: 04/01/2025 DS  
Permit Expires: 10/01/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: KRKH, Inc. 199 Sherwood Dr. Wood Dale, IL 60191 Du Page County Contact: Shilu Amin 630/345-0304	<b>FACILITY</b> - name and address where tanks are located: Gas Depot 17W532 Lake Street Addison, IL 60101 Du Page County Contact: Jigar Patel 630/782-6988
---	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Gasoline - Regular	10,000	Currently in use	Federal
6	Gasoline - Premium	8,000	Currently in use	Federal
7	Diesel Fuel	8,000	Currently in use	Federal

**Tank 5 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Replacing - Leak Detect - Piping - Sump Sensor
Leak Detection - Tank	Automatic Tank Gauging Dover Maglink LX Plus	Replacing - Leak Detect - Tank - Automatic Tank Gauging EBW Auto-Stik Jr.
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors With Monitor	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors

**Tank 6 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Replacing - Leak Detect - Piping - Sump Sensor
Leak Detection - Tank	Automatic Tank Gauging Dover Maglink LX Plus	Replacing - Leak Detect - Tank - Automatic Tank Gauging EBW Auto-Stik Jr.
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors With Monitor	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors

## Tank 7 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Replacing - Leak Detect - Piping - Sump Sensor
Leak Detection - Tank	Automatic Tank Gauging Dover Maglink LX Plus	Replacing - Leak Detect - Tank - Automatic Tank Gauging EBW Auto-Stik Jr.
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors With Monitor	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors


### Summary of Work

The existing tank monitoring and leak detection system will be replaced with a Dover, Progaugage system including tank interstitial sensors and sump sensors with positive shut down.

### Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: Ed Angell Phone: 708/474-3344 Email: ed.angell@bkequip.com Contractor License # IL1207 Exp. 2/14/2026

Sincerely,



Daniel Starks