



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 6000113
Permit #: 00403-2025CAT
Request Rec'd: 04/03/2025
Approval Date: 04/03/2025 DS
Permit Expires: 10/03/2025

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Mac's Convenience Stores, LLC 1100 Situs Court, Suite 100 Raleigh, NC 27606 (None) County Contact: Michele Alvarado 773/456-5280	FACILITY - name and address where tanks are located: Circle K #1353 5904 Old St Louis Rd. Belleville, IL 62223 St. Clair County Contact: Jason Jones 812/379-9227
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Diesel Fuel	8,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Tank	Impressed Current Cathodic Protection	Replacing - Corrosion Prot - Tank - Impressed Current Cathodic Protection

NACE Certified Designer
NACE Certified Designer Number
Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work

We will be trenching in 18-24 inches deep to repair wires on the anodes for the Diesel tank that are damaged and currently not cathodically protecting the UST.

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Berkeley Springs Instruments LLC 1 Quantum Circle Frostburg, MD 21532	Contact Person: Tina Lewis Phone: 262/720-6888 Email: james.davis@bsisentry.com Contractor License # IL002467 Exp. 8/20/2026

Sincerely,

Daniel Starks