



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 4045232
Permit #: 00412-2025UPG
Request Rec'd: 04/03/2025
Approval Date: 04/07/2025 DS
Permit Expires: 10/07/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|--|--|
| OWNER OF TANKS - Corporation, partnership, or other business entity: Meijer Great Lakes Limited Partnership 2929 Walker Avenue, NW Grand Rapids, MI 495449428 Contact: Erik Petrovoskis 616/735-7101 | FACILITY - name and address where tanks are located: Meijer Gas Station #269 3635 Vermillion St. Danville, IL 61832 Vermilion County Contact: Shauntell Murray 616/791-3747 |
|--|--|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 1 | Gasoline - Regular | 20,000 | Currently in use | Federal |
| 2 | Gasoline - Premium | 8,000 | Currently in use | Federal |
| 3 | Diesel Fuel | 8,000 | Currently in use | Federal |
| 4 | Diesel Fuel | 6,000 | Currently in use | Federal |
| 5 | E85 | 8,000 | Currently in use | Federal |

Dispensers on the Permit

| Dispenser | Action |
|-----------|-------------------------|
| 1/2 | Sump / Sensors Changing |
| 3/4 | Sump / Sensors Changing |
| 5/6 | Sump / Sensors Changing |
| 7/8 | Sump / Sensors Changing |
| 9/10 | Sump / Sensors Changing |

Dispenser 1/2 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|------------------------------------|--|
| Dispenser | Single Wall UDC Sump | Replacing - Dispenser - Single Wall UDC Sump |
| Leak Detection - Piping | Sump Sensor with positive shutdown | Reusing Existing |

Dispenser 3/4 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|------------------------------------|--|
| Dispenser | Single Wall UDC Sump | Replacing - Dispenser - Single Wall UDC Sump |
| Leak Detection - Piping | Sump Sensor with positive shutdown | Reusing Existing |

Dispenser 5/6 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|------------------------------------|--|
| Dispenser | Single Wall UDC Sump | Replacing - Dispenser - Single Wall UDC Sump |
| Leak Detection - Piping | Sump Sensor with positive shutdown | Reusing Existing |

Dispenser 7/8 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|------------------------------------|--|
| Dispenser | Single Wall UDC Sump | Replacing - Dispenser - Single Wall UDC Sump |
| Leak Detection - Piping | Sump Sensor with positive shutdown | Reusing Existing |

Dispenser 9/10 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|------------------------------------|--|
| Dispenser | Single Wall UDC Sump | Replacing - Dispenser - Single Wall UDC Sump |
| Leak Detection - Piping | Sump Sensor with positive shutdown | Reusing Existing |

Summary of Work

Sawcut and remove islands and concrete around the islands to access the UDC's for removal.

Cut back the Smith FG piping and remove the APT Poly sumps and replace with SBravo FG sumps.


Reroute the diesel piping to come from just one tank. Convert the diesel #2 tank to rec fuel and use existing piping to run to the closest UDC (9/10).

Repipe the existing Smith FG piping into the new SBravo FG sumps. Pour the islands to the same size and specs as before.

Special Contingencies

| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
|---|--|
| R. W. Mercer Company 2322 Brooklyn Road Jackson, MI 49203 | Contact Person: Tracy Saylor Phone: 517/206-1946 Email: dean@rwmercerc.com Contractor License # IL002211 Exp. 6/21/2025 |

Sincerely,



Daniel Starks