



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2040379
Permit #: 00421-2025CAT
Request Rec'd: 03/06/2025
Approval Date: 04/08/2025 SK
Permit Expires: 10/08/2025

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: South Shore Hospital 8012 S. Crandon Chicago, IL 60617 Cook County Contact: Arthur Franzese 773/768-0810	FACILITY - name and address where tanks are located: South Shore Hospital 8015 S. Luella Chicago, IL 60617 Cook County Contact: Arthur Franzese 773/768-0810
--	---

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Diesel Fuel	10,000	Currently in use	Federal
3	Diesel Fuel	1,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Cathodic Protection with Dielectric Coating	Replacing - Corrosion Prot - Piping - Sacrificial Anode Cathodic Protection

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Fiberglass Non-Corrosive	Replacing - Corrosion Prot - Piping - Sacrificial Anode Cathodic Protection

NACE Certified Designer
NACE Certified Designer Number
Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work

This facility does not have cathodic sacrificial anodes on the lines. It was discovered in 2015 that the facility only has cathodic on Tank #3 (the 1K tank).

Tank #3: 1 K tank - piping is copper (no CP)

During the testing from today - it is discovered that the line are still the same:

Tank#3: Copper Line

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Protanic, LLC 658 North Progress Drive PO Box 80265 Saukville, WI 53080	Contact Person: Kylie Krombach Phone: 262/268-1150 Email: danc@protanicinc.com Contractor License # IL1413 Exp. 9/26/2026

Sincerely,

Sean Keane