



**City of Chicago**  
**Department of Public Health**  
333 South State Street, Room 200  
Chicago, IL 60604  
312/745-3162  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2031759  
Permit #: 00442-2025UPG  
Request Rec'd: 04/10/2025  
Approval Date: 04/14/2025 SK  
Permit Expires: 10/15/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Cook County Provident Hospital 500 East 51st Street Chicago, IL 60610 Cook County Contact: Thomas Whalen 312/572-1101	<b>FACILITY</b> - name and address where tanks are located: Provident Hospital 500 East 51st Street Chicago, IL 60615 Cook County Contact: Thomas Whalen 312/572-1101
---	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Diesel Fuel	10,000	Currently in use	Federal
6	Diesel Fuel	10,000	Currently in use	Federal

**Tank 5 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Single Wall Transition Sump	New
Leak Detection - Piping	Sump Sensor	New

**Tank 6 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Single Wall Transition Sump	New
Leak Detection - Piping	Sump Sensor	New

**Summary of Work**

Installing two new transition sumps at basement wall of building

We are not installing sump sensors as we are only replacing sumps and not 20 or more of pipe or more than 50% of piping run

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: 630/878-6354 Email: jasonre@rstenstrom.com Contractor License # IL1890 Exp. 4/12/2026

Sincerely,

Sean Keane