



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Replacement of 00853-2024CAT

FOR OFFICE USE ONLY
Facility #: 2032445
Permit #: 00443-2025CAT
Request Rec'd: 04/14/2025
Approval Date: 04/15/2025 DS
Permit Expires: 10/15/2025

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: St. Francis Hospital 355 N. Ridge Ave. Evanston, IL 60202 Cook County Contact: Joe Stark 847/316-2466	FACILITY - name and address where tanks are located: St. Francis Hospital of Evanston 355 Ridge Ave. Evanston, IL 60202 Cook County Contact: Manfred Feldman 847/316-4131
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Diesel Fuel	10,000	Currently in use	Federal
2	Diesel Fuel	10,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Tank	Impressed Current Cathodic Protection	Replacing - Corrosion Prot - Tank - Impressed Current Cathodic Protection

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Tank	Impressed Current Cathodic Protection	Replacing - Corrosion Prot - Tank - Impressed Current Cathodic Protection

NACE Certified Designer
NACE Certified Designer Number
Method of Integrity Assessment of Tanks

Special Contingencies

Replacement Reason:

Delay during repairs do to structure damage to the building/basement.

Summary of Work

Replace the ground bed to include 6 MMO anodes, 300+ coke breeze bonding to the vents and pipe

PERSON, FIRM OR COMPANY PERFORMING WORK:

Tanknology
880 Church Road
Elgin, IL 60123

Contact Person: Linda Przydzial
Phone: 512/380-7117
Email: dhollander@tanknology.com
Contractor License # IL2089 Exp. 3/4/2026

Sincerely,



Daniel Starks