

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 2042094
Permit #: 00446-2025UPG
Request Rec'd: 04/15/2025
Approval Date:04/15/2025 DS
Permit Expires: 10/15/2025

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Windy Property Investments, LLC 545 Mannheim Road Bellwood, IL 60104

(None) County

Contact: Sam (Bassam) Hussein 708/897-8117

FACILITY

- name and address where tanks are located:

BP of Flossmoor - IL0027 3950 Vollmer Road Flossmoor, IL 60422 Cook County

Contact: Sam Hussein 708/897-8117

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Gasoline - Premium	15,000	Currently in use	Federal

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	Removing

Summary of Work

Removing Electronic leak detector ans installing 65PSI check valave as the line has 2 PLLDs as per OSFM inspector

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

Vaniel J. Starke

America Petropump Services LLC d/b/a Ampsco Services 4075 Fox Valley Center Dr., Unit 9

Aurora, IL 60504

Contact Person: Ravindra Penmatsa

Phone: 312/286-6722 Email: ravi@ampsco.net

Contractor License # IL002420 Exp. 3/13/2027

Sincerely,

Daniel Starks