

City of Chicago Department of Public Health

333 South State Street, Room 200 Chicago, IL 60604 312/745-3162 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 2016450
Permit #: 00454-2025UPG
Request Rec'd: 04/17/2025
Approval Date:04/18/2025 SK
Permit Expires: 10/20/2025

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Belmont Real Estate Group, LLC 8060 Lawndale Avenue Skokie, IL 60076 (None) County

Contact: Nasir Yaqoob 847/361-5927

FACILITY

- name and address where tanks are located:

Belmont & Milwaukee Shell 3181 N. Milwaukee Chicago, IL 60618

Cook County

Contact: Arun Nair 847/679-5398

Contractor License # IL002420 Exp. 3/13/2027

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
7	Ultra Low Sulfur Diesel	12,000	Currently in use	Federal

Tank 7 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Summary of Work

The Spill Failed Inspection so replacing it

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:				
America Petropump Services LLC d/b/a Ampsco Services 4075 Fox Valley Center Dr., Unit 9 Aurora, IL 60504	Contact Person: Ravindra Penmatsa Phone: 312/286-6722 Email: ravi@ampsco.net			

Sincerely,

Sean Keane