

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 2018605
Permit #: 00458-2025UPG
Request Rec'd: 04/18/2025
Approval Date:04/19/2025 DS
Permit Expires: 10/21/2025

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

HPT TA Properties, LLC 24601 Center Ridge Road Westlake, OH 44145 (None) County

Contact: Bonnie Parrino 440/808-7268

FACILITY

- name and address where tanks are located:

Morris Travel Center 21 Romines Drive Morris, IL 60450 Grundy County

Contact: Donna Barnard 815/942-5690

Tanks on the Permit For Piping Only

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Diesel Fuel	12,000	Currently in use	Federal

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Piping	Shear Valves	New

Summary of Work

Replacement of Main shear valve under high flow dispenser #1 due to current shear valve not fully holding when cycled. (I had to add a shear valve even though there was already one in place)

Special Contingencies

NOTE: UDC must be installed if not already existing

PERSON, FIRM OR COMPANY PERFORMING WORK:

Northern Indiana Mechanical 3311 East 15th avenue

Janiel J. Starke

Gary, IN 46403

Contact Person: Madeline Kingery

Phone: 219/963-1640

Email: nimco653@hotmail.com

Contractor License # IL292 Exp. 5/8/2025

Sincerely,

Daniel Starks