



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 3034997
Permit #: 00466-2025UPG
Request Rec'd: 04/17/2025
Approval Date: 04/21/2025 DS
Permit Expires: 10/21/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Oak Run Property Owners Association 1470 Knox Rd 1725 N Dahinda, IL 61428 Knox County Contact: Mike Davison 309/879-2603	FACILITY - name and address where tanks are located: Oak Run Country Store (FS Fuel 24) 1472 Knox Rd 1725N Dahinda, IL 61428 Knox County Contact: Cassidy Traff 309/879-2603
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Replacing - Leak Detect - Piping - Sump Sensor
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 300c	Replacing - Leak Detect - Tank - Automatic Tank Gauging EBW Auto-Stik Jr.

Summary of Work

REMOVING THE EBW TANK MONITOR AND INSTALL VEEDER ROOT TLS 300C WITH SUMP SENSOR

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
R. L. Hoener Company 2923 Gardner Expressway P. O. Box 1086 Quincy, IL 62305	Contact Person: Marty Jackson Phone: 217/223-2190 Email: kmajors@rlhoener.com Contractor License # IL2021 Exp. 5/22/2026

Sincerely,

Daniel Starks