



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY	
Facility #:	7023226
Permit #:	00467-2025UPG
Request Rec'd:	04/21/2025
Approval Date:	04/21/2025 DS
Permit Expires:	10/21/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Russell Oil Company 200 E. Main Galatia, IL 62935 Saline County Contact: Leon Russell 618/926-9180	FACILITY - name and address where tanks are located: ROC 1 Stop #12 201 North 1st Street Vienna, IL 62995 Johnson County Contact: Carl Brasher 618/268-4722
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
7	Gasoline - Regular	8,000	Currently in use	Federal
8	Gasoline - Regular	4,000	Currently in use	Federal
9	Diesel Fuel	4,000	Currently in use	Federal

Tank 7 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection

Tank 9 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection

Summary of Work

Remove existing wireleccs PLLD and replace with mechanical leak detectors.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
UPC Enterprises, LC d/b/a United Petroleum Service 128 Millwell Drive Maryland Heights, MO 63043	Contact Person: Terry Smith Phone: 314/241-3767 Email: tsmith@unitedpetro.com Contractor License # IL002402 Exp. 2/10/2026

Sincerely,

Daniel J. Starks

Daniel Starks