



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2011839
Permit #: 00471-2025ABN
Request Rec'd: 04/21/2025
Approval Date: 04/22/2025 SK
Permit Expires: 10/22/2025

Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: 4759 South Cicero Chicago, LLC 26 Mill Plain Road Danbury, CT 06811 (None) County Contact: Syed Kirmani 347/499-3835	FACILITY - name and address where tanks are located: BP 4759 South Cicero Chicago, IL 60632 Cook County Contact: Syed Kirmani 847/765-8507
--	---

Tanks on the Permit

* A combination of inert fill material is not allowed. The listed inert fill material is only allowed to fill the abandoned tank.

Tank #	Capacity	Product	Fill Material *
1	7,500	Gasoline - Regular	Inert material mixed with portland cement
2	7,500	Gasoline - Premium	Inert material mixed with portland cement

Explanation of Waiver for Abandonment

These two tanks are very near to Foundation and footings of the building. Also tanks are under the canopy. There is lot of risk for the foundation and footings wehn we try to remove these two tanks. Please approve the abandoning these two tanks .

Thanks

Innoavtive Constructions Tech LLC

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Innovative Constructions Technology LLC 245 W Roosevelt Rd Building 4, Unit 28 West Chicago, IL 60185	Contact Person: Raju penumatsa Phone: 630/747-3404 Email: iconstructions81@gmail.com Contractor License # IL002453 Exp. 2/7/2026

Sincerely,

Sean Keane