



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY
Facility #: 2042681
Permit #: 00326-2025UPG
Request Rec'd: 03/19/2025
Approval Date: 03/19/2025 DS
Amended Date: 04/22/2025 DS
Permit Expires: 09/19/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|---|---|
| OWNER OF TANKS - Corporation, partnership, or other business entity: Thumbs Up, Inc. 13801 South Halsted Riverdale, IL 608271607 Cook County Contact: Ghulam Dada 630/965-0785 | FACILITY - name and address where tanks are located: Citgo Gas Station 13801 South Halsted Riverdale, IL 608271607 Cook County Contact: 630/965-0785 |
|---|---|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 2 | Gasoline - Premium | 8,000 | Currently in use | Federal |
| 3 | Diesel Fuel | 4,000 | Currently in use | Federal |

Tank 2 Equipment

| Equipment Type | Permit Equipment | Action |
|--------------------------|------------------------------|---|
| Piping | Ball Valves | New |
| Piping | Other Steel Riser | New |
| Piping | Other Submersible Pump | New |
| Piping | Single Wall STP/Tanktop Sump | Replacing - Piping - Single Wall STP/Tanktop Sump |
| Leak Detection - Piping | Sump Sensor | Reusing Existing |
| Spill Containment Device | Double Wall Spill Bucket | Replacing - Spill Contain Device - Single Wall Spill Bucket |

Tank 3 Equipment

| Equipment Type | Permit Equipment | Action |
|--------------------------|--------------------------|---|
| Spill Containment Device | Double Wall Spill Bucket | Replacing - Spill Contain Device - Single Wall Spill Bucket |

Dispensers on the Permit

| Dispenser | Action |
|-----------|-------------------------|
| 1/2 | Sump / Sensors Changing |
| 3/4 | Sump / Sensors Changing |
| 5/6 | Sump / Sensors Changing |
| 7/8 | Sump / Sensors Changing |
| 9/10 | Sump / Sensors Changing |
| 11/12 | Sump / Sensors Changing |

Dispenser 1/2 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|---|--|
| Leak Detection - Piping | Sump Sensor with positive shutdown in Single Wall UDC Sump | Replacing - Leak Detect - Piping - Stand Alone Sump Sensor |

Dispenser 3/4 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|---|--|
| Leak Detection - Piping | Sump Sensor with positive shutdown in Single Wall UDC Sump | Replacing - Leak Detect - Piping - Stand Alone Sump Sensor |

Dispenser 5/6 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|---|--|
| Leak Detection - Piping | Sump Sensor with positive shutdown in Single Wall UDC Sump | Replacing - Leak Detect - Piping - Stand Alone Sump Sensor |

Dispenser 7/8 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|---|--|
| Leak Detection - Piping | Sump Sensor with positive shutdown in Single Wall UDC Sump | Replacing - Leak Detect - Piping - Stand Alone Sump Sensor |

Dispenser 9/10 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|---|--|
| Leak Detection - Piping | Sump Sensor with positive shutdown in Single Wall UDC Sump | Replacing - Leak Detect - Piping - Stand Alone Sump Sensor |

Dispenser 11/12 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|---|--|
| Leak Detection - Piping | Sump Sensor with positive shutdown in Single Wall UDC Sump | Replacing - Leak Detect - Piping - Stand Alone Sump Sensor |

Summary of Work

Replacing premium stp sump due to bad tank bung adapter and spill containers due to poor risers.

Replaced all stand alone UDC sensors with standard sensors wired to veeder root and enabled positive shutdown

Special Contingencies**Amendment Reason:**

sensor change

| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
|---|---|
| B & K Equipment Company 2939 175th Street Lansing, IL 60438 | Contact Person: Ed Angell Phone: 708/474-3344 Email: dj.white@bkequip.com Contractor License # IL1207 Exp. 2/14/2026 |

Sincerely,



Daniel Starks