



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 5020731  
Permit #: 00489-2025UPG  
Request Rec'd: 04/24/2025  
Approval Date: 04/24/2025 DS  
Permit Expires: 05/06/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for  
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Thorntons, LLC 2600 James Thornton Way Louisville, KY 40245 Contact: Maggie Sebaugh 502/572-1259	<b>FACILITY</b> - name and address where tanks are located: Thornton Oil #368 511 Keokuk Lincoln, IL 62656 Logan County Contact: Adam McGee 217/732-1993
---	--

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
5	Gasoline - Premium	12,000	Currently in use	Federal
6	Gasoline - Regular	12,000	Currently in use	Federal
7	Gasoline - Regular	12,000	Currently in use	Federal

**Tank 5 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Shear Valves	New

**Tank 6 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Shear Valves	New

**Tank 7 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Shear Valves	New

**Summary of Work**

Dispenser # 1/2 was bumped by a vehicle , We replaced 3 cracked sheer valves with EBW 662501902 DP Sheer Valves. we preformed a passing nitrogen test on all three product lines # 5,6,7 before opening the lines back up.

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Seneca Companies, Inc. 4140 East 14th Street PO Box 3360 Des Moines, IA 50313	Contact Person: Glen Davis Phone: 217/413-8119 Email: choenig@senecaco.com Contractor License # IL598 Exp. 2/23/2026

Sincerely,

*Daniel J. Starks*

Daniel Starks