



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2022344
Permit #: 00490-2025UPG
Request Rec'd: 04/24/2025
Approval Date: 04/24/2025 DS
Permit Expires: 10/24/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Governors State University University Parkway & Governors Highway University Park, IL 60466 Will County Contact: Carolyn Johnson 708/534-4515	FACILITY - name and address where tanks are located: Governors State University One University Parkway University Park, IL 60466 Will County Contact: Carolyn Johnson 708/534-4515
---	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
2	Gasoline - Regular	4,000	Currently in use	Federal
3	Gasoline - Regular	550	Currently in use	Federal
4	Diesel Fuel	550	Currently in use	Federal
5	Diesel Fuel	1,000	Currently in use	Federal

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 4B	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 4B	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 4B	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 350

Tank 5 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 4B	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 300c

Summary of Work

Replacing two Veeder Root consoles on site with new Veeder Root TLS4B consoles. No probes or sensors are changing

Special Contingencies**PERSON, FIRM OR COMPANY PERFORMING WORK:**

Stenstrom Petroleum Services Group
2422 Center Street
Rockford, IL 61108

Contact Person: Robert Stenstrom
Phone: 630/878-6354
Email: jasonre@rstenstrom.com
Contractor License # IL1890 Exp. 4/12/2026

Sincerely,



Daniel Starks