



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Revised

FOR OFFICE USE ONLY
Facility #: 6000699
Permit #: 00436-2025UPG
Request Rec'd: 04/10/2025
Approval Date: 04/11/2025 DS
Revision Date: 04/24/2025 DS
Permit Expires: 10/14/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Waif Rackley Land Investment, LLC P.O. Box 100 West Alton, MO 63386 (None) County Contact: Tom Parsons 618/580-7268	FACILITY - name and address where tanks are located: Little Nashville Truck Stop, LLC d/b/a Little Nashville Truck Stop 11700 State Route 127 Nashville, IL 62263 Washington County Contact: Murad Dayani 618/478-5777
---	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
6	B-11	10,000	Currently in use	Federal

Tank 6 Equipment

Equipment Type	Permit Equipment	Action
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Summary of Work

UPGRADE TANK 5 SINGLE WALL SPILL BUCKET TO A DOUBLE WALL SPILL BUCKET.

Special Contingencies

Revision Reason:

Changed the tank number from 5 to 6, as the contractor mistakenly permitted the wrong tank

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Neumayer Equipment Company, Inc. 5060 Arsenal Street St. Louis, MO 63139	Contact Person: Jimmy Spiros Phone: 314/772-4501 Email: testing@neumayerequipment.com Contractor License # IL1502 Exp. 3/26/2026

Sincerely,

Daniel Starks