

## Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 2044262
Permit #: 00516-2025UPG
Request Rec'd: 04/30/2025
Approval Date:04/30/2025 DS
Permit Expires: 10/30/2025

# <u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

#### THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

**OWNER OF TANKS** 

- Corporation, partnership, or other business entity:

Village of Franklin Park 9500 W. Belmont Ave. Franklin Park, IL 60131

Cook County

Contact: Mark Cwik 847/671-8253

**FACILITY** 

- name and address where tanks are located:

Village of Franklin Park 9360 Franklin Avenue Franklin Park, IL 60131

Cook County

Contact: Mark Cwik 847/671-8252

#### **Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal
2	Diesel Fuel	10,000	Currently in use	Federal

#### Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS - 4i	Removing

#### Tank 2 Equipment

<b>Equipment Type</b>	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS - 4i	Removing

#### **Summary of Work**

Removing tank monitoring as method of tank lead detection. Site will use interstitial monitoring (also listed as a method)

### **Special Contingencies**

Janiel J. Starky

PERSON, FIRM OR COMPANY PERFORMING WORK:

B & K Equipment Company
2939 175th Street
Lansing, IL 60438

Contact Person: Ed Angell
Phone: 708/474-3344
Email: ben.olthoff@bkequip.com
Contractor License # IL1207 Exp. 2/14/2026

Sincerely,

**Daniel Starks**