



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2006350
Permit #: 00528-2025UPG
Request Rec'd: 05/01/2025
Approval Date: 05/02/2025 DS
Permit Expires: 11/05/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Lehigh Gas Wholesale Services 645 Hamilton, Suite 400 Allentown, PA 18101 (None) County Contact: Jeremy Holland 610/625-8061	FACILITY - name and address where tanks are located: IL0081 246 W. Lake Street Addison, IL 60101 Du Page County Contact: Jose Tharathattel 846/680-5831
--	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	12,000	Currently in use	Federal
2	Gasoline - Regular	12,000	Currently in use	Federal
3	Gasoline - Premium	10,000	Currently in use	Federal
4	Diesel Fuel	4,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	New
Corrosion Protection - Piping	Fiberglass Non-Corrosive	New
Corrosion Protection - Piping	Impressed Current Cathodic Protection	Removing
Leak Detection - Tank	Automatic Tank Gauging Red Jacket Pro Max	New
Piping	Fiberglass Double Wall Ameron Dualoy 3000/LCX	New
Piping	Galvanized Steel Single Wall Piping	Removing
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Fiberglass Non-Corrosive	New
Corrosion Protection - Piping	Impressed Current Cathodic Protection	Removing
Leak Detection - Tank	Automatic Tank Gauging Red Jacket Pro Max	New
Piping	Ball Valves	New
Piping	Fiberglass Double Wall Ameron Dualoy 3000/LCX	New
Piping	Flex Connector Steel	New
Piping	Single Wall STP/Tanktop Sump	New
🔍 Leak Detection - Piping	Sump Sensor with positive shutdown	New
Piping	Steel Single Wall Piping	Removing
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	New
Corrosion Protection - Piping	Fiberglass Non-Corrosive	New
Corrosion Protection - Piping	Impressed Current Cathodic Protection	Removing
Leak Detection - Tank	Automatic Tank Gauging Red Jacket Pro Max	New
Piping	Fiberglass Double Wall Ameron Dualoy 3000/LCX	New
Piping	Steel Single Wall Piping	Removing
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket


Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Corrosion Protection - Piping	Fiberglass Non-Corrosive	New
Corrosion Protection - Piping	Impressed Current Cathodic Protection	Removing
Leak Detection - Tank	Automatic Tank Gauging Red Jacket Pro Max	New
Piping	Ball Valves	New
Piping	Fiberglass Double Wall Ameron Dualoy 3000/LCX	New
Piping	Fiberglass Single Wall Piping Ameron	Removing
Piping	Flex Connector Steel	New
Piping	Single Wall STP/Tanktop Sump	New
 Leak Detection - Piping	Sump Sensor with positive shutdown	New
Spill Containment Device	Double Wall Spill Bucket	Replacing - Spill Contain Device - Single Wall Spill Bucket


Dispensers on the Permit

Dispenser	Action
1/2	Sump / Sensors Changing
3/4	Sump / Sensors Changing
5/6	Sump / Sensors Changing
7/8	Sump / Sensors Changing
9/10	Sump / Sensors Changing
11/12	Sump / Sensors Changing
13/14	Sump / Sensors Changing


Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
 Leak Detection - Piping	Sump Sensor with positive shutdown	New


Dispenser 3/4 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
 Leak Detection - Piping	Sump Sensor with positive shutdown	New

Dispenser 5/6 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
 Leak Detection - Piping	Sump Sensor with positive shutdown	New

Dispenser 7/8 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
 Leak Detection - Piping	Sump Sensor with positive shutdown	New

Dispenser 9/10 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
Leak Detection - Piping	Sump Sensor with positive shutdown	New

Dispenser 11/12 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
Leak Detection - Piping	Sump Sensor with positive shutdown	New

Dispenser 13/14 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Replacing - Dispenser - Single Wall UDC Sump
Leak Detection - Piping	Sump Sensor with positive shutdown	New


Summary of Work

Removing all existing piping, spill buckets and any installed containments. All new UDC's and STP containments to be installed with positive shutdown sensors. New STP's and leak detectors. Removing existing TLS 300 and installing Red Jacket ProMax. Islands to be free formed with u-shaped crash protection. Dispensers to be re-used.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: 815/398-6250 Email: johnbu@rstenstrom.com Contractor License # IL1890 Exp. 4/12/2026

Sincerely,



Daniel Starks

For Office Use Only**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Installed in Single Wall STP/Tanktop Sump	Removing

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Piping	Not Installed STP/Tanktop Sump	Removing

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Installed in Single Wall STP/Tanktop Sump	Removing

Tank 4 Equipment

Equipment Type	Permit Equipment	Action
Piping	Not Installed STP/Tanktop Sump	Removing

Dispenser 1/2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump	Removing

Dispenser 3/4 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump	Removing

Dispenser 5/6 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump	Removing

Dispenser 7/8 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump	Removing

Dispenser 9/10 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump	Removing

Dispenser 11/12 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump	Removing

Dispenser 13/14 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump	Removing