



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2021804  
Permit #: 00535-2025ABN  
Request Rec'd: 05/01/2025  
Approval Date: 05/05/2025 DS  
Permit Expires: 11/05/2025

**Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Mac's Convenience Stores, LLC 1100 Situs Court, Suite 100 Raleigh, NC 27606 (None) County Contact: Michele Alvarado 773/456-5280	<b>FACILITY</b> - name and address where tanks are located: Circle K #4700180 3 Gladiola Momence, IL 60954 Kankakee County Contact: Elizabeth Patterson 984/389-1765
--	--

**Tanks on the Permit**

\* A combination of inert fill material is not allowed. The listed inert fill material is only allowed to fill the abandoned tank.

Tank #	Capacity	Product	Fill Material *
5	6,000	Gasoline - Regular	Inert material mixed with portland cement

**Explanation of Waiver for Abandonment**

Tank #5 labeled in the Site Plan as RUL1 is too be abandoned. It is located in between canopy and Premium tank. Due to loss of support to tanks and canopy structures, this tank is too be abandoned. We will be using Inert Slurry filling and capping off piping/vents at tank location.

**Location of Tanks Being Abandoned**

Tank #5 labeled in the Site Plan as RUL1 is too be abandoned. It is located in between canopy and Premium tank. Due to loss of support to tanks and canopy structures, this tank is too be abandoned. We will be using Inert Slurry filling and capping off piping/vents at tank location.

**Location of Piping Being Abandoned**

Piping shares a trench with active piping as shown in drawing

**Special Contingencies**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Ron Anderson Phone: 630/484-7374 Email: KeenanA@andersonpump.com Contractor License # IL002275 Exp. 6/10/2025

Sincerely,

Daniel Starks