



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2002739
Permit #: 00544-2025UPG
Request Rec'd: 05/06/2025
Approval Date: 05/06/2025 DS
Permit Expires: 11/06/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Bukhari Food Mart, Inc. 6900 Canton Lincolnwood, IL 60645 Cook County Contact: Fazil Yaqoob 847/338-7278	FACILITY - name and address where tanks are located: Marathon 3800 West Oakton Street Skokie, IL 60076 Cook County Contact: Akhter Raza 847/982-0901
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
10	Gasoline - Regular	10,000	Currently in use	Federal
11	Gasoline - Premium	6,000	Currently in use	Federal
12	Diesel Fuel	4,000	Currently in use	Federal

Tank 10 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Alarm	Replacing - Overfill Prev Device - Ball Float Vent Valve OPW 53VML

Tank 11 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Alarm	Replacing - Overfill Prev Device - Ball Float Vent Valve OPW 53VML

Tank 12 Equipment

Equipment Type	Permit Equipment	Action
Overfill Prevention Device	Overfill Alarm	New

Summary of Work

Installing overfill alarm as method of overfill prevention. Diesel tank has an OPV drop tube. Adding overfill alarm as secondary to Diesel

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
B & K Equipment Company 2939 175th Street Lansing, IL 60438	Contact Person: Ed Angell Phone: 708/474-3344 Email: ben.olthoff@bkequip.com Contractor License # IL1207 Exp. 2/14/2026

Sincerely,

Daniel J. Starks

Daniel Starks