



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2043141
Permit #: 00547-2025UPG
Request Rec'd: 05/06/2025
Approval Date: 05/07/2025 DS
Permit Expires: 11/07/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Woodman's Food Market, Inc. 2631 Liberty Lane Janesville, WI 535450741 (None) County Contact: Deb Arnold 608/754-8382	FACILITY - name and address where tanks are located: Woodman's Gas/Lube & Car Wash 150 Hansen Boulevard North Aurora, IL 60542 Kane County Contact: Victor Samperio 608/754-8382
---	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
8	Gasoline - Regular	30,000	Currently in use	Federal

Tank 8 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Incon TS 550 EVO	Removing
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors With Monitor	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors

Summary of Work

Permitting for Interstitial Monitoring Only - Currently on Equipment list (REMOVING ATG as Leak Detection method)

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: 815/398-6250 Email: amberp@rstenstrom.com Contractor License # IL1890 Exp. 4/12/2026

Sincerely,

Daniel Starks