



City of Chicago
Department of Public Health
333 South State Street, Room 200
Chicago, IL 60604
312/745-3162
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2022990
Permit #: 00549-2025CAT
Request Rec'd: 05/06/2025
Approval Date: 05/07/2025 SK
Permit Expires: 11/07/2025

Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|--|--|
| OWNER OF TANKS - Corporation, partnership, or other business entity: 2357 Property, LLC 2357 E. 79th Street Chicago, IL 60649 Cook County Contact: 847/293-2916 | FACILITY - name and address where tanks are located: Citgo Quick Stop 2357 East 79th Street Chicago, IL 60649 Cook County Contact: Moktar Nasser 847/293-2916 |
|--|--|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 1 | Gasoline - Premium | 10,000 | Currently in use | Federal |
| 2 | Gasoline - Regular | 10,000 | Currently in use | Federal |
| 3 | Gasoline - Regular | 12,000 | Currently in use | Federal |

Tank 1 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------------|---------------------------------------|---|
| Corrosion Protection - Piping | Impressed Current Cathodic Protection | Replacing - Corrosion Prot - Piping - Impressed Current Cathodic Protection |
| Corrosion Protection - Tank | Impressed Current Cathodic Protection | Replacing - Corrosion Prot - Tank - Impressed Current Cathodic Protection |

Tank 2 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------------|---------------------------------------|---|
| Corrosion Protection - Piping | Impressed Current Cathodic Protection | Replacing - Corrosion Prot - Piping - Impressed Current Cathodic Protection |
| Corrosion Protection - Tank | Impressed Current Cathodic Protection | Replacing - Corrosion Prot - Tank - Impressed Current Cathodic Protection |

Tank 3 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------------|---------------------------------------|---|
| Corrosion Protection - Piping | Impressed Current Cathodic Protection | Replacing - Corrosion Prot - Piping - Impressed Current Cathodic Protection |
| Corrosion Protection - Tank | Impressed Current Cathodic Protection | Replacing - Corrosion Prot - Tank - Impressed Current Cathodic Protection |

NACE Certified Designer
NACE Certified Designer Number
Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work

Replacing 5 anodes on existing impressed current system.

| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
|--|--|
| Cardinal Compliance LLC 415 W. Golf Rd. Unit 28M-N Arlington Heights, IL 60005 | Contact Person: Chris Derro Phone: 708/717-2676 Email: cderro@cardinalcompliance.net Contractor License # IL002418 Exp. 3/21/2027 |

Sincerely,

Sean Keane