



**OFFICE OF THE ILLINOIS STATE FIRE MARSHAL**  
**Division of Technical Services**  
 1035 Stevenson Drive  
 Springfield, Illinois 62703-4259  
 (217)524-7605

<u>FOR OFFICE USE ONLY</u>
Facility # 5-011116
Permit # 01870-2006ENT
Request Rec'd 12/14/2006
Amended Date
Approval Date 12/14/2006 JC
Permit Expires 6/14/2007

**Permit for ENTRY into Underground Storage Tank(s) for Petroleum and Hazardous Substances.**

Permission to enter underground storage tank(s) is hereby granted. Such tank entry shall not commence until the contractor the permit was issued to or an employee of that contractor (this does not include a subcontractor) shall establish a date certain to perform the UST activity by contacting the Office of the State Fire Marshal, Division of Petroleum and Chemical Safety, by telephone at the Springfield office between 8:30 a.m. and 12:00 p.m., at which time a mutually agreed upon date and time for the UST activity shall be scheduled. **THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<p><b>(1) <u>OWNER OF TANKS</u></b> - Corporation, partnership, or other business entity:          Moto Mart, Inc.          721 W. Main Street, P.O. Box 122          Belleville, IL 62222-0122          Contact: Joseph Hooten (618) 233-6756</p>	<p><b>(2) <u>FACILITY</u></b> - name and address where tanks are located:          Gillespie Moto Mart          415 S. Macoupin          Gillespie, Macoupin Co., IL          Contact: Joseph B Hooten (217) 839-4011</p>
--	---

**(3) ENTRY OF TANKS:**

- (a) *Number and size of tanks being entered:* (TK # 1) - 8,000 gallons
- (b) *Type of tanks:*
- (c) *Product stored in each tank:* (TK # 1) - Gasoline
- (d) *Reason for tanks being entered:* To enter and chip off existing lining.
- (e) *Manway accessible at grade:*

**(4) The owner must notify this Office when completion of tank entry has occurred, on the Notification for Underground Storage Tank Form. This form can be obtained at [www.state.il.us/osfm](http://www.state.il.us/osfm) or by calling (217)785-1020.**

**(5) SPECIAL CONTINGENCIES:** Tank relining, lining inspection and entry permit work in reference to manways/manholes must abide by sections 170.430(a)(1)(C) and (D), 170.430(b)(5), and 170.430(c)(10). Contractor will enter and chip off the existing lining.

<p><b>(6) <u>PERSON, FIRM OR COMPANY PERFORMING WORK:</u></b></p> <p align="right">Contact Person:          Phone:          Contractor Registration #    Exp.</p>
---

Sincerely,

cc: Storage Tank Safety Specialist -  
 Fire Department -  
 Office Coordinator -  
 Division File  
 (Rev. - 1/98)