

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 3006053
Permit #: 00559-2025CAT
Request Rec'd: 05/08/2025
Approval Date:05/08/2025 DS
Permit Expires: 11/10/2025

<u>Permit for INSTALL ATION, UPGRADE, or REPAIR of CATHODIC PROTECTION SYSTEM of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances</u>

Permission to install, upgrade, or repair cathodic protection of underground storage tank(s) or piping is hereby granted. Such installations, upgrades, or repairs must be in complete accordance with acceptable materials and procedures as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Mac's Convenience Stores, LLC 1100 Situs Court, Suite 100 Raleigh, NC 27606 (None) County

Contact: Michele Alvarado 773/456-5280

FACILITY

- name and address where tanks are located:

Mac's #1212 1827 18th Avenue East Moline, IL 62144 Rock Island County

Contact: Erica Haskins 217/243-1839

Tanks on the Permit For Piping Only

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 8 | Gasoline - Regular | 10,000 | Currently in use | Federal |
| 9 | Diesel Fuel | 10,000 | Currently in use | Federal |
| 10 | Gasoline - Premium | 10,000 | Currently in use | Federal |

Tank 8 Equipment

| Equipment Type | Permit Equipment | Action |
|------------------------|----------------------------------|--|
| Corrosion Protection - | Sacrificial Anode Flex Connector | Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex |
| Piping | - STP | Connector - STP |

Tank 9 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------------------------|------------------|---|
| Corrosion Protection - Piping | | Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - STP |

Tank 10 Equipment

| Equipment Type | Permit Equipment | Action |
|----------------------------------|------------------|---|
| Corrosion Protection - Piping | | Replacing - Corrosion Prot - Piping - Sacrificial Anode Flex Connector - STP |

NACE Certified Designer
NACE Certified Designer Number
Method of Integrity Assessment of Tanks

Special Contingencies

Summary of Work

INSTALL MAG ANODES TO THE DISPENSER FLEX CONNECTORS PER NOV.

PERSON, FIRM OR COMPANY PERFORMING WORK:

Tanknology 880 Church Road Elgin, IL 60123

Contact Person: Linda Przydzial Phone: 512/380-7117

Email: dhollander@tanknology.com Contractor License # IL2089 Exp. 3/4/2026

Sincerely, Daniel J. Starks

Daniel Starks