



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 7035861
Permit #: 00562-2025UPG
Request Rec'd: 05/08/2025
Approval Date: 05/08/2025 DS
Permit Expires: 11/10/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|--|--|
| OWNER OF TANKS - Corporation, partnership, or other business entity: I Khodal, LLC 14711 State Hwy 37 Whittington, IL 62897 Franklin County Contact: Bobby Patel 816/807-0317 | FACILITY - name and address where tanks are located: Lake Zone Phillips 66 14711 State Hwy 37 Whittington, IL 62897 Franklin County Contact: Jalpa Patel 618/629-2780 |
|--|--|

Tanks on the Permit For Piping Only

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|-------------|----------|------------------|------------------|
| 3 | Diesel Fuel | 4,000 | Currently in use | Federal |

Tank 3 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|---|---|
| Piping | Flexible Double Wall OmegaFlex DoubleTrac | Replacing - Piping - Flexible Double Wall |
| Piping | Single Wall STP/Tanktop Sump | Replacing - Piping - Single Wall STP/Tanktop Sump |
| Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispensers on the Permit

| Dispenser | Action |
|-----------|-------------------------|
| 7 | Sump / Sensors Changing |

Dispenser 7 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|------------------------------------|--|
| Dispenser | Single Wall UDC Sump | Replacing - Dispenser - Single Wall UDC Sump |
| Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Summary of Work

NOTE: Installing new sumps and sensors only

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

Mid-South Steel Products, Inc.
2071 Corporate Circle Drive PO Box 277
Cape Girardeau, MO 63703

Contact Person: Billy Thorne
Phone: 573/335-5529
Email: billy@midsouthsteel.com
Contractor License # IL1194 Exp. 8/17/2026

Sincerely,



Daniel Starks

For Office Use Only**Tank 3 Equipment**

| Equipment Type | Permit Equipment | Action |
|-------------------------|--|----------|
| Leak Detection - Piping | Piping Sump Sensors Not Regulated Not Installed in Single Wall STP/Tanktop Sump | Removing |

Dispenser 7 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|--|----------|
| Leak Detection - Piping | Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump | Removing |