



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2018874  
Permit #: 00569-2025ABN  
Request Rec'd: 05/09/2025  
Approval Date: 05/12/2025 DS  
Permit Expires: 11/13/2025

**Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: RDK Ventures, LLC 1120 W. Warner Rd. Tempe, AZ 85284 (None) County Contact: Michele Alvarado 773/456-5280	<b>FACILITY</b> - name and address where tanks are located: Circle K #6893 1001 W. Route 34 Plano, IL 60178 Kendall County Contact: Elizabeth Sauser 708/748-3496
---	---

**Tanks on the Permit**

\* A combination of inert fill material is not allowed. The listed inert fill material is only allowed to fill the abandoned tank.

Tank #	Capacity	Product	Fill Material *
8	10,000	Gasoline - Premium	Inert material mixed with portland cement

**Explanation of Waiver for Abandonment**

Premium Tank #8 is located 51feet away from Route 34, and 55 feet away from Pence street. It is North of tank #6, and tank #7, sided by side. Due to loss of support to adjacent tank structures, this condemned tank is too be abandoned. All associated vent and product piping to be capped off at tankhole. Tank will be washed, cleaned, and then filled with an Inert Slurry Material. Highlighted in the site plan is tank #8 and associated piping.

**Location of Tanks Being Abandoned**

Premium Tank #8 is located 51feet away from Route 34, and 55 feet away from Pence street. It is North of tank #6, and tank #7, sided by side. Due to loss of support to adjacent tank structures, this condemned tank is too be abandoned. All associated vent and product piping to be capped off at tankhole. Tank will be washed, cleaned, and then filled with an Inert Slurry Material. Highlighted in the site plan is tank #8 and associated piping.

**Location of Piping Being Abandoned**

Premium Tank #8 is located 51feet away from Route 34, and 55 feet away from Pence street. It is North of tank #6, and tank #7, sided by side. Due to loss of support to adjacent tank structures, this condemned tank is too be abandoned. All associated vent and product piping to be capped off at tankhole. Tank will be washed, cleaned, and then filled with an Inert Slurry Material. Highlighted in the site plan is tank #8 and associated piping.


**CONTAMINATED SITE!**

**IEMA Number**  
1991-1768

**Special Contingencies**

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Anderson Pump Service, Inc. 19659 South 97th Avenue Mokena, IL 60448	Contact Person: Ron Anderson Phone: 630/484-7374 Email: KeenanA@andersonpump.com Contractor License # IL002275 Exp. 6/10/2025

Sincerely,

  
\_\_\_\_\_

Daniel Starks