



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov  
**Amended**

**FOR OFFICE USE ONLY**  
Facility #: 2020330  
Permit #: 00536-2025UPG  
Request Rec'd: 05/05/2025  
Approval Date: 05/05/2025 DS  
Amended Date: 05/14/2025 DS  
Permit Expires: 11/05/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: North Suburban Petro Mart, Inc. 7760 North Nordica, Apt. 2-D Niles, IL 60714 Cook County Contact: Jim Hussaini 312/363-7120	<b>FACILITY</b> - name and address where tanks are located: Arlington Heights Mobil 102 West Northwest Highway Arlington Heights, IL 60004 Cook County Contact: Jim Hussaini 847/255-2421
---	---

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Diesel Fuel	10,000	Currently in use	Federal
2	Gasoline - Premium	10,000	Currently in use	Federal
3	Gasoline - Regular	12,000	Currently in use	Federal

**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Mechanical Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - Electronic Pressurized Line Leak Detection
Piping	Fiberglass Single Wall Piping Ameron	New
Piping	Flex Connector Steel	New
Piping	Shear Valves	New

**Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Single Wall Piping Ameron	New
Piping	Flex Connector Steel	New
Piping	Shear Valves	New

**Tank 3 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Single Wall Piping Ameron	New
Piping	Flex Connector Steel	New
Piping	Shear Valves	New

**Dispensers on the Permit**

Dispenser	Action
7/8	Sump / Sensors Changing

**Dispenser 7/8 Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New

**Summary of Work**

Cutting back existing steel pipe to install new singlewall UDC. Connecting new singlewall fiberglass pipe to existing steel pipe run back into UDC. New flex connectors and shear valves.

Not installing sump sensor.

\*Amendment: Diesel wireless leak detector crumbled apart during testing due to severe corrosion. Replaced with mechanical leak detector.

**Special Contingencies****Amendment Reason:**


Diesel wireless leak detector crumbled apart during testing due to severe corrosion. Replaced with mechanical leak detector.

**PERSON, FIRM OR COMPANY PERFORMING WORK:**

B & K Equipment Company  
2939 175th Street  
Lansing, IL 60438

Contact Person: Ed Angell  
Phone: 708/474-3344  
Email: dj.white@bkequip.com  
Contractor License # IL1207 Exp. 2/14/2026

Sincerely,



Daniel Starks

**For Office Use Only****Dispenser 7/8 Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Not Installed UDC Sump	Removing