



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
 1035 Stevenson Drive  
 Springfield, IL 62703  
 217/785-1020  
 www.sfm.illinois.gov  
 SFM.DPCS@illinois.gov

<b>FOR OFFICE USE ONLY</b>	
Facility #:	2028982
Permit #:	00596-2025UPG
Request Rec'd:	05/08/2025
Approval Date:	05/14/2025 DS
Permit Expires:	11/14/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Ann & Robert H. Lurie Children's Hospital of Chicago 225 E. Chicago Avenue Chicago, IL 60611 Cook County Contact: Joe Stark 312/227-0912	<b>FACILITY</b> - name and address where tanks are located: Childrens Memorial Medical Facility 2308 Enterprise Drive Westchester, IL 60153 Cook County Contact: Mike Wozniak 773/880-3964
----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**Tanks on the Permit For Piping Only**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Diesel Fuel	550	Currently in use	Federal

**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Chase	Replacing - Piping - Fiberglass Chase
Piping	Steel Single Wall Piping	Replacing - Piping - Steel Single Wall Piping

**Summary of Work**

Beacon will be removing approx. 60' of supply/return 1" steel pipe for generator. At the point of removal we will 90 towards building and pick up new above-ground piping run to generator day tank.

**Special Contingencies**

**NOTE: Only approximately 10' of piping to be installed and it is a European suction system, which nullifies the need for double wall piping.**

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Beacon SSI, Inc. 10526 W. Cermak Rd Suite 302 Westchester, IL 60154	Contact Person: Patrick Ferriter Phone: 708/917-2263 Email: patrick.ferriter@beaconssi.com Contractor License # IL002336 Exp. 1/27/2027

Sincerely,

Daniel Starks