



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY
Facility #: 2020330
Permit #: 00536-2025UPG
Request Rec'd: 05/05/2025
Approval Date: 05/05/2025 DS
Amended Date: 05/14/2025 DS
Permit Expires: 11/05/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: North Suburban Petro Mart, Inc. 7760 North Nordica, Apt. 2-D Niles, IL 60714 Cook County Contact: Jim Hussaini 312/363-7120	FACILITY - name and address where tanks are located: Arlington Heights Mobil 102 West Northwest Highway Arlington Heights, IL 60004 Cook County Contact: Jim Hussaini 847/255-2421
---	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Diesel Fuel	10,000	Currently in use	Federal
2	Gasoline - Premium	10,000	Currently in use	Federal
3	Gasoline - Regular	12,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Single Wall Piping Ameron	New
Piping	Flex Connector Steel	New
Piping	Shear Valves	New

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Single Wall Piping Ameron	New
Piping	Flex Connector Steel	New
Piping	Shear Valves	New

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Single Wall Piping Ameron	New
Piping	Flex Connector Steel	New
Piping	Shear Valves	New

Dispensers on the Permit

Dispenser	Action
7/8	Sump / Sensors Changing

Dispenser 7/8 Equipment

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	New
↩ Leak Detection - Piping	Sump Sensor with positive shutdown	New

Summary of Work

Cutting back existing steel pipe to install new singlewall UDC. Connecting new singlewall fiberglass pipe to existing steel pipe run back into UDC. New flex connectors and shear valves.

Not installing sump sensor.

*Amendment: Diesel wireless leak detector crumbled apart during testing due to severe corrosion. Replaced with mechanical leak detector.

*Amendment: Wireless leak detector installed on Diesel, did not install mechanical.

Special Contingencies**Amendment Reason #1:**

Diesel wireless leak detector crumbled apart during testing due to severe corrosion. Replaced with mechanical leak detector.

Amendment Reason #2:


Mechanical leak detector was not installed on Diesel.

PERSON, FIRM OR COMPANY PERFORMING WORK:

B & K Equipment Company
2939 175th Street
Lansing, IL 60438

Contact Person: Ed Angell
Phone: 708/474-3344
Email: dj.white@bkequip.com
Contractor License # IL1207 Exp. 2/14/2026

Sincerely,



Daniel Starks

For Office Use Only**Dispenser 7/8 Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Not Installed UDC Sump	Removing