

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 2023034
Permit #: 00600-2025UPG
Request Rec'd: 05/15/2025
Approval Date:05/15/2025 DS
Permit Expires: 11/17/2025

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

FCL, Inc.

698 Albany Lane Des Plaines, IL 60016

Cook County

Contact: FEBIN THOMAS 847/372-8531

FACILITY

- name and address where tanks are located:

Rand and River BP 1530 Rand Road Des Plaines, IL 60016

Cook County

Contact: Febin Thomas 847/699-9526

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 2 | Gasoline - Regular | 8,000 | Currently in use | Federal |

Tank 2 Equipment

| Equipment Type | Permit Equipment | Action |
|-----------------------|----------------------------------|--|
| Leak Detection - | Mechanical Pressurized Line Leak | Replacing - Leak Detect - Piping - Electronic Pressurized Line |
| Piping | Detection | Leak Detection |

Summary of Work

Replace electronic leak detector with mechanical leak detector.

Special Contingencies

Vaniel J. Starke

| PERSON, FIRM OR COMPANY PERFORMING WORK: | | | | |
|---|---|--|--|--|
| B & K Equipment Company 2939 175th Street Lansing, IL 60438 | Contact Person: Ed Angell Phone: 708/474-3344 Email: dj.white@bkequip.com Contractor License # IL1207 Exp. 2/14/2026 | | | |

Sincerely,

Daniel Starks