

## Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 2036850
Permit #: 00609-2025UPG
Request Rec'd: 05/16/2025
Approval Date:05/16/2025 DS
Permit Expires: 11/18/2025

# <u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

#### THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

**OWNER OF TANKS** 

- Corporation, partnership, or other business entity:

Pilot Travel Centers, LLC 5508 Lonas Rd. Knoxville, TN 37909

**Knox County** 

Contact: Joey Cupp 865/588-7488

**FACILITY** 

- name and address where tanks are located:

Pilot Travel Center #236 301 Ridge Road Minooka, IL 60447 Grundy County

Contact: Brian Gill 815/467-4416

#### **Tanks on the Permit**

| Tank # | Product            | Capacity | Tank Status      | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 8      | Gasoline - Premium | 12,000   | Currently in use | Federal          |

#### **Tank 8 Equipment**

| Equipment Type           | Permit Equipment         | Action  |
|--------------------------|--------------------------|---|
| Spill Containment Device | Double Wall Spill Bucket | Replacing - Spill Contain Device - Single Wall Spill Bucket |

#### **Summary of Work**

Esiting spill bucket has hole in it. Upgrading to double wall.

### **Special Contingencies**

Janiel J. Starke

| PERSON, FIRM OR COMPANY PERFORMING WORK:                               |  |  |  |  |
|--|--|--|--|--|
| Northern Indiana Mechanical<br>3311 East 15th avenue<br>Gary, IN 46403 | Contact Person: Madeline Kingery<br>Phone: 219/963-1640<br>Email: nimco653@hotmail.com<br>Contractor License # IL292 Exp. 5/9/2027 |  |  |  |

Sincerely,

Daniel Starks