



**Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety**

1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**Extended  
Replacement of 01274-2024INS**

**FOR OFFICE USE ONLY**

Facility #: 2047809  
Permit #: 01547-2024INS  
Request Rec'd: 11/26/2024  
Approval Date: 12/03/2024 DS  
Extension Date: 05/21/2025  
Permit Expires: 12/03/2025

**Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted. The tank owner must submit a Notification for Underground Storage Tanks form prior to the scheduling of the final schedule at: <https://webapps.sfm.illinois.gov/USTPortal/NotificationForm>.


**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE EXTENSION DATE.**

|   |   |
|---|---|
| <b>OWNER OF TANKS</b><br>- Corporation, partnership, or other business entity:<br>Hodgkins Tollroad Plaza Partners LLC<br>29 Scenic Drive<br>Gallatin Gateway, MT 59730<br>Contact: Duckie Huynh 639/414-9332 | <b>FACILITY</b><br>- name and address where tanks are located:<br>Duckee's Travel Center<br>10000 W 75th Street<br>Hodgkins, IL 60525<br>Cook County<br>Contact: John Siff 639/414-9332 |
|---|---|


**Tanks on the Permit**

| Tank # | Product            | Capacity | Tank Status          | Regulated Status |
|--------|--------------------|----------|----------------------|------------------|
| 1      | Gasoline - Regular | 20,000   | Installed/Not in Use | Federal          |
| 2      | Gasoline - Premium | 12,000   | Installed/Not in Use | Federal          |
| 3      | E15                | 8,000    | Installed/Not in Use | Federal          |
| 4      | Diesel Fuel        | 20,000   | Installed/Not in Use | Federal          |


## Tank 1 Equipment

| Equipment Type  | Permit Equipment   | Action |
|---|--|--------|
| Corrosion Protection - Piping   | Flexible Non-Corrosive   | New    |
| Corrosion Protection - Piping   | Polyethylene Chase   | New    |
| Corrosion Protection - Tank   | Fiberglass Non-Corrosive   | New    |
| Leak Detection - Piping   | Electronic Pressurized Line Leak Detection                         | New    |
| Leak Detection - Tank   | Automatic Tank Gauging Veeder Root TLS 450 Plus                    | New    |
| Leak Detection - Tank   | Hydrostatic Reservoir Interstitial Monitoring Sensors with monitor | New    |
| Overfill Prevention Device  | Overfill Alarm   | New    |
| Piping  | Ball Valves  | New    |
| Piping  | Fiberglass Single Wall Piping Ameron                               | New    |
| Piping  | Flex Connector Steel   | New    |
| Piping  | Flexible Double Wall A.P.T. Poly Tech                              | New    |
| Piping  | Other Steel Riser  | New    |
| Piping  | Other Submersible Pump   | New    |
| Piping  | Polyethylene Chase   | New    |
| Piping  | Shear Valves   | New    |
| Piping  | Single Wall STP/Tanktop Sump                                       | New    |
|  Leak Detection - Piping | Sump Sensor with positive shutdown                                 | New    |
| Spill Containment Device  | Double Wall Spill Bucket   | New    |
| Tank  | Fiberglass Brine Filled Double Wall Containment Solutions          | New    |


## Tank 2 Equipment

| Equipment Type  | Permit Equipment   | Action |
|---|--|--------|
| Corrosion Protection - Piping   | Flexible Non-Corrosive   | New    |
| Corrosion Protection - Piping   | Polyethylene Chase   | New    |
| Corrosion Protection - Tank   | Fiberglass Non-Corrosive   | New    |
| Leak Detection - Piping   | Electronic Pressurized Line Leak Detection                         | New    |
| Leak Detection - Tank   | Automatic Tank Gauging Veeder Root TLS 450 Plus                    | New    |
| Leak Detection - Tank   | Hydrostatic Reservoir Interstitial Monitoring Sensors with monitor | New    |
| Overfill Prevention Device  | Overfill Alarm   | New    |
| Piping  | Ball Valves  | New    |
| Piping  | Fiberglass Single Wall Piping Ameron                               | New    |
| Piping  | Flex Connector Steel   | New    |
| Piping  | Flexible Double Wall A.P.T. Poly Tech                              | New    |
| Piping  | Other Steel Riser  | New    |
| Piping  | Other Submersible Pump   | New    |
| Piping  | Polyethylene Chase   | New    |
| Piping  | Shear Valves   | New    |
| Piping  | Single Wall STP/Tanktop Sump                                       | New    |
|  Leak Detection - Piping | Sump Sensor with positive shutdown                                 | New    |
| Spill Containment Device  | Double Wall Spill Bucket   | New    |
| Tank  | Fiberglass Brine Filled Double Wall Containment Solutions          | New    |

### Tank 3 Equipment

| Equipment Type  | Permit Equipment   | Action |
|---|--|--------|
| Corrosion Protection - Piping   | Flexible Non-Corrosive   | New    |
| Corrosion Protection - Piping   | Polyethylene Chase   | New    |
| Corrosion Protection - Tank   | Fiberglass Non-Corrosive   | New    |
| Leak Detection - Piping   | Electronic Pressurized Line Leak Detection                         | New    |
| Leak Detection - Tank   | Automatic Tank Gauging Veeder Root TLS 450 Plus                    | New    |
| Leak Detection - Tank   | Hydrostatic Reservoir Interstitial Monitoring Sensors with monitor | New    |
| Overfill Prevention Device  | Overfill Alarm   | New    |
| Piping  | Ball Valves  | New    |
| Piping  | Fiberglass Single Wall Piping Ameron                               | New    |
| Piping  | Flex Connector Steel   | New    |
| Piping  | Flexible Double Wall A.P.T. Poly Tech                              | New    |
| Piping  | Other Steel Riser  | New    |
| Piping  | Other Submersible Pump   | New    |
| Piping  | Polyethylene Chase   | New    |
| Piping  | Shear Valves   | New    |
| Piping  | Single Wall STP/Tanktop Sump                                       | New    |
|  Leak Detection - Piping | Sump Sensor with positive shutdown                                 | New    |
| Spill Containment Device  | Double Wall Spill Bucket   | New    |
| Tank  | Fiberglass Brine Filled Double Wall Containment Solutions          | New    |


### Tank 4 Equipment

| Equipment Type  | Permit Equipment   | Action |
|---|--|--------|
| Corrosion Protection - Piping   | Flexible Non-Corrosive   | New    |
| Corrosion Protection - Piping   | Polyethylene Chase   | New    |
| Corrosion Protection - Tank   | Fiberglass Non-Corrosive   | New    |
| Leak Detection - Piping   | Electronic Pressurized Line Leak Detection                         | New    |
| Leak Detection - Tank   | Automatic Tank Gauging Veeder Root TLS 450 Plus                    | New    |
| Leak Detection - Tank   | Hydrostatic Reservoir Interstitial Monitoring Sensors with monitor | New    |
| Overfill Prevention Device  | Overfill Alarm   | New    |
| Piping  | Ball Valves  | New    |
| Piping  | Fiberglass Single Wall Piping Ameron                               | New    |
| Piping  | Flex Connector Steel   | New    |
| Piping  | Flexible Double Wall A.P.T. Poly Tech                              | New    |
| Piping  | Other Steel Riser  | New    |
| Piping  | Other Submersible Pump   | New    |
| Piping  | Polyethylene Chase   | New    |
| Piping  | Shear Valves   | New    |
| Piping  | Single Wall STP/Tanktop Sump                                       | New    |
|  Leak Detection - Piping | Sump Sensor with positive shutdown                                 | New    |
| Spill Containment Device  | Double Wall Spill Bucket   | New    |
| Tank  | Fiberglass Brine Filled Double Wall Containment Solutions          | New    |


## Dispensers on the Permit

| Dispenser | Action |
|-----------|--------|
| 1/2       | New    |
| 3/4       | New    |
| 5/6       | New    |
| 7/8       | New    |
| 9/10      | New    |
| 11/12     | New    |
| 13/14     | New    |
| 15/16     | New    |
| 17        | New    |
| 17s/18m   | New    |
| 18s/19m   | New    |
| 19S/20M   | New    |
| 20S/21M   | New    |
| 21s       | New    |


### Dispenser 1/2 Equipment

| Equipment Type  | Permit Equipment                   | Action |
|---|------------------------------------|--------|
| Dispenser   | Single Wall UDC Sump               | New    |
|  Leak Detection - Piping | Sump Sensor with positive shutdown | New    |


### Dispenser 3/4 Equipment

| Equipment Type  | Permit Equipment                   | Action |
|---|------------------------------------|--------|
| Dispenser   | Single Wall UDC Sump               | New    |
|  Leak Detection - Piping | Sump Sensor with positive shutdown | New    |


### Dispenser 5/6 Equipment

| Equipment Type  | Permit Equipment                   | Action |
|---|------------------------------------|--------|
| Dispenser   | Single Wall UDC Sump               | New    |
|  Leak Detection - Piping | Sump Sensor with positive shutdown | New    |


### Dispenser 7/8 Equipment

| Equipment Type  | Permit Equipment                   | Action |
|---|------------------------------------|--------|
| Dispenser   | Single Wall UDC Sump               | New    |
|  Leak Detection - Piping | Sump Sensor with positive shutdown | New    |

### Dispenser 9/10 Equipment

| Equipment Type  | Permit Equipment                   | Action |
|---|------------------------------------|--------|
| Dispenser   | Single Wall UDC Sump               | New    |
|  Leak Detection - Piping | Sump Sensor with positive shutdown | New    |

### Dispenser 11/12 Equipment

| Equipment Type  | Permit Equipment                   | Action |
|---|------------------------------------|--------|
| Dispenser   | Single Wall UDC Sump               | New    |
|  Leak Detection - Piping | Sump Sensor with positive shutdown | New    |

**Dispenser 13/14 Equipment**

| Equipment Type            | Permit Equipment                   | Action |
|---------------------------|------------------------------------|--------|
| Dispenser                 | Single Wall UDC Sump               | New    |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New    |

**Dispenser 15/16 Equipment**

| Equipment Type            | Permit Equipment                   | Action |
|---------------------------|------------------------------------|--------|
| Dispenser                 | Single Wall UDC Sump               | New    |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New    |

**Dispenser 17 Equipment**

| Equipment Type            | Permit Equipment                   | Action |
|---------------------------|------------------------------------|--------|
| Dispenser                 | Single Wall UDC Sump               | New    |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New    |

**Dispenser 17s/18m Equipment**

| Equipment Type            | Permit Equipment                   | Action |
|---------------------------|------------------------------------|--------|
| Dispenser                 | Single Wall UDC Sump               | New    |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New    |

**Dispenser 18s/19m Equipment**

| Equipment Type            | Permit Equipment                   | Action |
|---------------------------|------------------------------------|--------|
| Dispenser                 | Single Wall UDC Sump               | New    |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New    |

**Dispenser 19S/20M Equipment**

| Equipment Type            | Permit Equipment                   | Action |
|---------------------------|------------------------------------|--------|
| Dispenser                 | Single Wall UDC Sump               | New    |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New    |

**Dispenser 20S/21M Equipment**

| Equipment Type            | Permit Equipment                   | Action |
|---------------------------|------------------------------------|--------|
| Dispenser                 | Single Wall UDC Sump               | New    |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New    |

**Dispenser 21s Equipment**

| Equipment Type            | Permit Equipment                   | Action |
|---------------------------|------------------------------------|--------|
| Dispenser                 | Single Wall UDC Sump               | New    |
| ↳ Leak Detection - Piping | Sump Sensor with positive shutdown | New    |

**General Requirements**

USTs shall be installed to safeguard against movement by anchoring in accordance with manufacturer's instructions. There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

**Summary of Work**

Installing new location per the attached.

**Special Contingencies****Replacement Reason:**


Permit requires a new permit to complete since used all of the amendments

**PERSON, FIRM OR COMPANY PERFORMING WORK:**

Anderson Pump Service, Inc.  
19659 South 97th Avenue  
Mokena, IL 60448

Contact Person: Ron Anderson  
Phone: 708/243-9081  
Email: Steve@andersonpump.com  
Contractor License # IL002275 Exp. 5/21/2026

Sincerely,



---

Daniel Starks