



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 2047882  
Permit #: 00630-2025ABN  
Request Rec'd: 05/21/2025  
Approval Date: 05/21/2025 DS  
Permit Expires: 11/24/2025

**Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Chang Hee Lee, Won-Mi Chang, Won Lee 914 Shermer Rd. Northbrook, IL 60062 Cook County Contact: Chang Hee Lee 847/814-7737	<b>FACILITY</b> - name and address where tanks are located: Dart Custom Cleaners 4929 W. Oakton Street Skokie, IL 60077 Cook County Contact: Chang Hee Lee 847/814-7737
---	---

**Tanks on the Permit**

\* A combination of inert fill material is not allowed. The listed inert fill material is only allowed to fill the abandoned tank.

Tank #	Capacity	Product	Fill Material *
1	500	Fuel Oil	Inert material mixed with portland cement

**Explanation of Waiver for Abandonment**

UST less than 5 feet from building foundation

**Location of Tanks Being Abandoned**

Tank is located in close proximity to an existing building.

**CONTAMINATED SITE!**

**IEMA Number**

2025-0363

**Special Contingencies**

**NOTES:** No piping mentioned in summary, but will either need to be added to this permit and drawing or a separate removal pemrit must be submitted for. STSS, please verify that the tank cannot be removed, as the drawing isn't very clear.

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
RW Collins Company 7225 West 66th Street Chicago, IL 60638	Contact Person: Lisa Kruse Phone: 779/301-5966 Email: slucero@rwcollins.com Contractor License # IL772 Exp. 2/9/2026

Sincerely,

Daniel Starks