



Office of the Illinois State Fire Marshal  
Division of Petroleum and Chemical Safety  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov

**FOR OFFICE USE ONLY**  
Facility #: 3034948  
Permit #: 00635-2025UPG  
Request Rec'd: 05/20/2025  
Approval Date: 05/23/2025 DS  
Permit Expires: 11/25/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: Casey's Retail Company 3305 SE Delaware Ave. P.O. Box 3004 Ankeny, IA 50021 Contact: Lee Lytle 515/446-6231	<b>FACILITY</b> - name and address where tanks are located: Casey's General Store #2660 509 South East 2nd Street Galva, IL 61434 Henry County Contact: Mike Brady 515/965-6238
--	---

**Tanks on the Permit For Piping Only**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Diesel Fuel	6,000	Currently in use	Federal
2	Gasoline - Regular	10,000	Currently in use	Federal

**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Flexible Double Wall A.P.T. Poly Tech P150SC	Replacing - Piping - Flexible Double Wall

**Tank 2 Equipment**

Equipment Type	Permit Equipment	Action
Piping	Flexible Double Wall A.P.T. Poly Tech	Replacing - Piping - Flexible Double Wall

**Dispensers on the Permit**

Dispenser	Action
5/6	Replacing - 5/6

**Dispenser 5/6 Equipment**

Equipment Type	Permit Equipment	Action
Dispenser	Single Wall UDC Sump	Reusing Existing
Leak Detection - Piping	Sump Sensor with positive shutdown	New

**Summary of Work**

Replacing island 5/6. Lowering existing shear valves.

**Special Contingencies**

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: 815/209-6640 Email: natem@rstenstrom.com Contractor License # IL1890 Exp. 4/12/2026

Sincerely,

*Daniel J. Starks*

Daniel Starks

For Office Use Only		
Dispenser 5/6 Equipment		
Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Piping Sump Sensors Not Regulated Not Installed in Single Wall UDC Sump	Removing