



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
 1035 Stevenson Drive
 Springfield, IL 62703
 217/785-1020
 www.sfm.illinois.gov
 SFM.DPCS@illinois.gov
Revised

FOR OFFICE USE ONLY	
Facility #:	2035865
Permit #:	00488-2025UPG
Request Rec'd:	04/24/2025
Approval Date:	04/24/2025 DS
Revision Date:	05/29/2025 DS
Permit Expires:	10/24/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Garfield300, Inc. 15401 S. Cottage Grove Dolton, IL 60419 (None) County Contact: Cyriac K Chandy 630/673-3382	FACILITY - name and address where tanks are located: Dolton Mini Mart, Inc. 15401 S. Cottage Grove Ave. Dolton, IL 60419 Cook County Contact: Ali Salahi 708/655-5050
---	--

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
9	Gasoline - Premium	8,000	Currently in use	Federal
10	Gasoline - Regular	10,000	Currently in use	Federal

Tank 9 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Replacing - Leak Detect - Piping - Sump Sensor
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors With Monitor	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors With Monitor

Tank 10 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Replacing - Leak Detect - Piping - Sump Sensor
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors With Monitor	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors With Monitor

Summary of Work

Installing output relay module in ATG for positive shutdown of mechanical line leak detection. Tank testing method will remain interstitial monitoring only.

Special Contingencies

Revision Reason:

Changed sensors to reflect proper work

PERSON, FIRM OR COMPANY PERFORMING WORK:

Cardinal Compliance LLC
415 W. Golf Rd. Unit 28M-N
Arlington Heights, IL 60005

Contact Person: Chris Derro
Phone: 708/717-2676
Email: cderro@cardinalcompliance.net
Contractor License # IL002418 Exp. 3/21/2027

Sincerely,



Daniel Starks