



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2022807
Permit #: 00661-2025UPG
Request Rec'd: 05/29/2025
Approval Date: 05/29/2025 DS
Permit Expires: 12/02/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|--|---|
| OWNER OF TANKS - Corporation, partnership, or other business entity: AG & Sons, Inc. 1601 New Lenox Road Joliet, IL 60433 Will County Contact: Tahir Ghafoor 815/727-6222 | FACILITY - name and address where tanks are located: Interstate Shell 1601 New Lenox Road Joliet, IL 60433 Will County Contact: Tahir Ghafoor 815/727-6222 |
|--|---|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|------------------|------------------|
| 6 | Gasoline - Regular | 12,000 | Currently in use | Federal |
| 7 | Gasoline - Premium | 12,000 | Currently in use | Federal |
| 8 | Diesel Fuel | 12,000 | Currently in use | Federal |

Tank 6 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|------------------------------|---|
| Piping | Single Wall STP/Tanktop Sump | Replacing - Piping - Single Wall STP/Tanktop Sump |
| Leak Detection - Piping | Sump Sensor | Reusing Existing |

Tank 7 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|------------------------------|---|
| Piping | Single Wall STP/Tanktop Sump | Replacing - Piping - Single Wall STP/Tanktop Sump |
| Leak Detection - Piping | Sump Sensor | Reusing Existing |

Tank 8 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|------------------------------|---|
| Piping | Single Wall STP/Tanktop Sump | Replacing - Piping - Single Wall STP/Tanktop Sump |
| Leak Detection - Piping | Sump Sensor | Reusing Existing |

Summary of Work

REPLACING ALL STP SUMPS WITH SINGLEWALL HDPE SUMPS.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

Cardinal Compliance LLC
415 W. Golf Rd. Unit 28M-N
Arlington Heights, IL 60005

Contact Person: Chris Derro
Phone: 708/717-2676
Email: cderro@cardinalcompliance.net
Contractor License # IL002418 Exp. 3/21/2027

Sincerely,



Daniel Starks