



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 3001237
Permit #: 00686-2025ABN
Request Rec'd: 06/03/2025
Approval Date: 06/04/2025 DS
Permit Expires: 12/04/2025

**Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Tremont Oil Company 200 E. Pearl St. P.O. Box Tremont, IL 61568 Tazewell County Contact: Tom Gibson 309/925-2251	FACILITY - name and address where tanks are located: Tremont Oil Company 200 East Pearl Street Tremont, IL 61568 Tazewell County Contact: Tom Gibson 309/925-2251
--	--

Tanks on the Permit

* A combination of inert fill material is not allowed. The listed inert fill material is only allowed to fill the abandoned tank.

Tank #	Capacity	Product	Fill Material *
23	1,000	Diesel Fuel	Inert material mixed with portland cement

Explanation of Waiver for Abandonment

UST to be abandoned is located directly adjacent to an active pump island and and piping for a separate UST. The piping for the tank that is to be abandoned also crosses active product lines. Removal would comprise the pump island and piping. Will properly abandon UST and piping.

Location of Tanks Being Abandoned

UST to be abandoned is located directly adjacent to an active pump island and and piping for a separate UST. The piping for the tank that is to be abandoned also crosses active product lines. Removal would comprise the pump island and piping

Location of Piping Being Abandoned

UST to be abandoned is located directly adjacent to an active pump island and and piping for a separate UST. The piping for the tank that is to be abandoned also crosses active product lines. Removal would comprise the pump island and piping

CONTAMINATED SITE!

IEMA Number

2025-0382

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
RCRA, Inc. d/b/a Earth Services 10903 Prestwick Drive Benton, IL 62812	Contact Person: Josh Appleton Phone: 618/218-4958 Email: earthservices@earthservices.us Contractor License # IL002364 Exp. 8/7/2025

Sincerely,

Daniel J. Starks

Daniel Starks