



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2007202
Permit #: 00693-2025UPG
Request Rec'd: 06/04/2025
Approval Date: 06/05/2025 DS
Permit Expires: 12/05/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Williams Hayward Protective Coatings, Inc. 5241 West 70th Place Bedford Park, IL 60638 Cook County Contact: Thomas Kurcz 708/563-5184	FACILITY - name and address where tanks are located: Williams Hayward Protective Coating 5241 W. 70th Place Bedford Park, IL 60638 Cook County Contact: Tommy Kurcz 708/218-7589
---	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
20	Hazardous Substance	1,200	Currently in use	Federal
21	Texanol	1,200	Currently in use	Federal
22	Butyl Cellosolve	1,200	Currently in use	Federal
23	Mineral Spirits	1,200	Currently in use	Federal
24	Dibutyl Phthalate	1,200	Currently in use	Federal
25	Methyl Carbitol	1,200	Currently in use	Federal
26	Tolulol	1,000	Currently in use	Federal
27	Morpholine	1,000	Currently in use	Federal
28	n-Butyl Alcohol	1,000	Currently in use	Federal
29	Hazardous Substance	1,000	Currently in use	Federal

Tank 20 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Pneumercator TMS 4000	Replacing - Leak Detect - Tank - Automatic Tank Gauging Pneumercator TMS 3000

Tank 21 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Pneumercator TMS 4000	Replacing - Leak Detect - Tank - Automatic Tank Gauging Pneumercator TMS 3000

Tank 22 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Pneumercator TMS 4000	Replacing - Leak Detect - Tank - Automatic Tank Gauging Pneumercator TMS 3000

Tank 23 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Pneumercator TMS 4000	Replacing - Leak Detect - Tank - Automatic Tank Gauging Pneumercator TMS 3000

Tank 24 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Pneumercator TMS 4000	Replacing - Leak Detect - Tank - Automatic Tank Gauging Pneumercator TMS 3000

Tank 25 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Pneumercator TMS 4000	Replacing - Leak Detect - Tank - Automatic Tank Gauging Pneumercator TMS 3000

Tank 26 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Pneumercator TMS 4000	Replacing - Leak Detect - Tank - Automatic Tank Gauging Pneumercator TMS 3000

Tank 27 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Pneumercator TMS 4000	Replacing - Leak Detect - Tank - Automatic Tank Gauging Pneumercator TMS 3000

Tank 28 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Pneumercator TMS 4000	Replacing - Leak Detect - Tank - Automatic Tank Gauging Pneumercator TMS 3000

Tank 29 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Pneumercator TMS 4000	Replacing - Leak Detect - Tank - Automatic Tank Gauging Pneumercator TMS 3000

Summary of Work

Beacon is replacing the existing Pneumercator TMS3000 with a Pneumercator 4000. Tank Leak Detection will be via existing Tank Annular sensors. Lines are European Safe Suction - no sensors required.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Beacon SSI, Inc. 10526 W. Cermak Rd Suite 302 Westchester, IL 60154	Contact Person: Patrick Ferriter Phone: 708/917-2263 Email: patrick.ferriter@beaconssi.com Contractor License # IL002336 Exp. 1/27/2027

Sincerely,



Daniel Starks