

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov FOR OFFICE USE ONLY

Facility #: 4039778
Permit #: 00713-2025UPG
Request Rec'd: 06/09/2025
Approval Date:06/09/2025 DS
Permit Expires: 12/09/2025

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

- Corporation, partnership, or other business entity:

Murphy Oil USA, Inc. 200 E. Peach Street El Dorado, AR 71730 (None) County

Contact: John Moore 870/677-6116

FACILITY

- name and address where tanks are located:

Murphy Oil USA #6554 105 Dettro Drive Mattoon, IL 61938 Coles County

Contact: Kathy Arthur 870/862-6411

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	12,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Piping	Flex Connector Steel	New
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
► Leak Detection - Piping	Sump Sensor	Reusing Existing

Summary of Work

changing sub unit and flex hose on the rul tank.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:

Neumayer Equipment Company, Inc. 5060 Arsenal Street St. Louis, MO 63139

Janiel y. Starke

Contact Person: Jimmy Spiros

Phone: 314/772-4501

Email: testing@neumayerequipment.com Contractor License # IL1502 Exp. 3/26/2026

Sincerely,

Daniel Starks