



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2019799
Permit #: 00718-2025UPG
Request Rec'd: 05/09/2025
Approval Date: 06/10/2025 DS
Permit Expires: 12/10/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Vitran Illinois, LLC 12225 Stephens Warren, MI 48089 (None) County Contact: Craig Stamper 586/939-7000	FACILITY - name and address where tanks are located: Central Transport 2105 W. 162nd Street Markham, IL 60428 Cook County Contact: Ryan Wells 215/948-7900
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
3	Diesel Fuel	30,000	Currently in use	Federal

Tank 3 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall STP/Tanktop Sump	Replacing - Leak Detect - Piping - Sump Sensor with positive shutdown
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 4B	Replacing - Leak Detect - Tank - Automatic Tank Gauging Simmons Sirvey Corp. Caldwell CITLDS
Leak Detection - Tank	Non-Discriminating Interstitial Monitoring Sensors	Replacing - Leak Detect - Tank - Non-Discriminating Interstitial Monitoring Sensors

Dispensers on the Permit

Dispenser	Action
MASTER 1/MASTER2	Sump / Sensors Changing
SAT 1	Sump / Sensors Changing
SAT 2	Sump / Sensors Changing

Dispenser MASTER 1/MASTER2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	Replacing - Leak Detect - Piping - Sump Sensor with positive shutdown

Dispenser SAT 1 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	Replacing - Leak Detect - Piping - Sump Sensor with positive shutdown

Dispenser SAT 2 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Sump Sensor with positive shutdown in Single Wall UDC Sump	Replacing - Leak Detect - Piping - Sump Sensor with positive shutdown

Summary of Work

Replacing the existing Simmons tank gauge/leak detection console with A Veeder Root TLS4 that includes the following new equipment:

- (1) Interstitial liquid sensor.
- (3) dispenser sump liquid sensors.
- (1) Tank top STP liquid sensor.
- (1) In Tank level probe with water float.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Crowne Industries, Ltd. 651 S. Sutton Road #214 Streamwood, IL 60107	Contact Person: Robert Sumoski Phone: 630/201-4967 Email: bob@crownetank.com Contractor License # IL002345 Exp. 5/16/2026

Sincerely,



Daniel Starks