



Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2038346
Permit #: 00720-2025UPG
Request Rec'd: 06/10/2025
Approval Date: 06/10/2025 DS
Permit Expires: 12/10/2025

Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Casey's Retail Company 3305 SE Delaware Ave. P.O. Box 3004 Ankeny, IA 50021 Contact: Lee Lytle 515/446-6231	FACILITY - name and address where tanks are located: Casey's General Store #2181 743 Bedford Road (West Route 6) Morris, IL 60450 Grundy County Contact: Julie Melville 515/965-6238
--	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Gasoline - Regular	10,000	Currently in use	Federal
2	Diesel Fuel	10,000	Currently in use	Federal

Tank 1 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Single Wall Piping Ameron	Replacing - Piping - Fiberglass Single Wall Piping Ameron

Tank 2 Equipment

Equipment Type	Permit Equipment	Action
Piping	Fiberglass Single Wall Piping Ameron	Replacing - Piping - Fiberglass Single Wall Piping Ameron

Summary of Work

Permit is for vent piping only. RUL and DSL vents are tied together. Breaking vent connection, remaking and separating vent piping as necessary.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Stenstrom Petroleum Services Group 2422 Center Street Rockford, IL 61108	Contact Person: Robert Stenstrom Phone: 815/520-5292 Email: trevorh@rstenstrom.com Contractor License # IL1890 Exp. 4/12/2026

Sincerely,

Daniel Starks