



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2027733
Permit #: 00727-2025UPG
Request Rec'd: 06/11/2025
Approval Date: 06/15/2025 DS
Permit Expires: 12/16/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: Central DuPage Hospital Association 25 N. Winfield Road Winfield, IL 60199 Du Page County Contact: Michael Schoewe 630/933-1600	FACILITY - name and address where tanks are located: Central DuPage Hospital 25 N. Winfield Road Winfield, IL 60199 Du Page County Contact: Jeff Wesley 630/933-1600
---	---

Tanks on the Permit

Tank #	Product	Capacity	Tank Status	Regulated Status
10	Diesel Fuel	25,000	Currently in use	Federal
11	Diesel Fuel	25,000	Currently in use	Federal
12	Diesel Fuel	20,000	Currently in use	Federal

Tank 10 Equipment

Equipment Type	Permit Equipment	Action
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Leak Detection - Piping	Sump Sensor	Reusing Existing

Tank 11 Equipment

Equipment Type	Permit Equipment	Action
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Leak Detection - Piping	Sump Sensor	Reusing Existing

Tank 12 Equipment

Equipment Type	Permit Equipment	Action
Leak Detection - Piping	Electronic Pressurized Line Leak Detection	Replacing - Leak Detect - Piping - American with Annual Prec Line Testing Suction
Piping	Other Submersible Pump	New
Piping	Single Wall STP/Tanktop Sump	Replacing - Piping - Single Wall STP/Tanktop Sump
Leak Detection - Piping	Sump Sensor	Reusing Existing


Summary of Work

Replace tank sumps for tanks 10, 11, and 12. Install new submersible pump and plld for tank 12.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Metro Environmental Contractors, Inc. dba Metro Tank & Pump Company 1111 West Dundee Road Wheeling, IL 600903936	Contact Person: Warren Cherner Phone: 847/465-4000 Email: info@metrotank.com Contractor License # IL102 Exp. 2/7/2026

Sincerely,



Daniel Starks