



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY
Facility #: 2032445
Permit #: 00746-2025ABN
Request Rec'd: 06/16/2025
Approval Date: 06/17/2025 DS
Permit Expires: 12/17/2025

**Permit for ABANDONMENT-IN-PLACE of Underground Storage Tank(s) and Piping for
Petroleum and Hazardous Substances**

Permission to abandon- in- place underground storage tank(s) or piping is hereby granted. Such abandonment must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175, and 176. The contractor the permit was issued to shall establish a date certain to perform the UST activity by shall establish a date certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account If the Storage Tank Safety Specialist (STSS) observes evidence of a release, the owner, operator or designated representative of the UST owner/operator must notify the Illinois Emergency Management Agency (IEMA). The incident number shall be given to the STSS prior to his/her leaving the site.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS - Corporation, partnership, or other business entity: St. Francis Hospital 355 N. Ridge Ave. Evanston, IL 60202 Cook County Contact: Joe Stark 847/316-2466	FACILITY - name and address where tanks are located: St. Francis Hospital of Evanston 355 Ridge Ave. Evanston, IL 60202 Cook County Contact: Manfred Feldman 847/316-4131
---	--

Tanks on the Permit

* A combination of inert fill material is not allowed. The listed inert fill material is only allowed to fill the abandoned tank.

Tank #	Capacity	Product	Fill Material *
1	10,000	Diesel Fuel	Inert material mixed with portland cement
2	10,000	Diesel Fuel	Inert material mixed with portland cement

Explanation of Waiver for Abandonment

Tanks are located against (2) building locations in a small alley way.
Removal would require extensive structural shoring.

Location of Tanks Being Abandoned

Tanks are in very close proximity to a building and removal would undermine the structural integrity of this building.

Special Contingencies

PERSON, FIRM OR COMPANY PERFORMING WORK:	
Crowne Industries, Ltd. 651 S. Sutton Road #214 Streamwood, IL 60107	Contact Person: Robert Sumoski Phone: 630/201-4967 Email: bob@crownetank.com Contractor License # IL002345 Exp. 9/8/2025

Sincerely,

Daniel Starks