

Office of the Illinois State Fire Marshal Division of Petroleum and Chemical Safety

1035 Stevenson Drive Springfield, IL 62703 217/785-1020 www.sfm.illinois.gov SFM.DPCS@illinois.gov

FOR OFFICE USE ONLY

Facility #: 6002467
Permit #: 00749-2025UPG
Request Rec'd: 06/17/2025
Approval Date:06/17/2025 DS
Permit Expires: 12/17/2025

<u>Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for</u> <u>Petroleum and Hazardous Substances</u>

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

OWNER OF TANKS

Fayette County

- Corporation, partnership, or other business entity:

South Central FS, Inc.

405 S. Banker Street P.O. Box 629

Effingham, IL 62401

Contact: Joseph Meinhart 217/342-9231

FACILITY

- name and address where tanks are located:

South Central FS, Inc. 1800 Hillsboro Road Vandalia, IL 62471 Fayette County

Contact: Tina Tinker 618/283-1368

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|---------|----------|------------------|------------------|
| 9 | B-11 | 12,000 | Currently in use | Federal |

Tank 9 Equipment

| Equipment Type | Permit Equipment | Action |
|--------------------------|--------------------------|---|
| Spill Containment Device | Double Wall Spill Bucket | Replacing - Spill Contain Device - Single Wall Spill Bucket |

Summary of Work

Replacing single wall spill containment manhole with new double wall manhole.

Special Contingencies

Janiel J. Starke

| PERSON, FIRM OR COMPANY PERFORMING WORK: | | | | |
|---|---|--|--|--|
| Total Petroleum Service Company 2421 Washington Road Washington, IL 61571 | Contact Person: Cheri McCoy Phone: 309/694-8224 Email: Tom.Oltman@TotalPetroleum.net Contractor License # IL1079 Exp. 2/8/2026 | | | |

Sincerely,

Daniel Starks