



**Office of the Illinois State Fire Marshal
Division of Petroleum and Chemical Safety**
1035 Stevenson Drive
Springfield, IL 62703
217/785-1020
www.sfm.illinois.gov
SFM.DPCS@illinois.gov
Amended

FOR OFFICE USE ONLY
Facility #: 5003096
Permit #: 00341-2025INS
Request Rec'd: 03/24/2025
Approval Date: 03/24/2025 DS
Amended Date: 06/18/2025 DS
Permit Expires: 09/24/2025

Permit for INSTALLATION of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances

Permission to install underground storage tank(s) or piping is hereby granted. Such installation must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted. The tank owner must submit a Notification for Underground Storage Tanks form prior to the scheduling of the final schedule at: <https://webapps.sfm.illinois.gov/USTPortal/NotificationForm>.

THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.

| | |
|---|---|
| OWNER OF TANKS - Corporation, partnership, or other business entity: Home Oil Company, Inc. 104 East Broad Street P.O. Box 45 Raymond, IL 62560 Montgomery County Contact: Jerry Wagahoff 217/229-3213 | FACILITY - name and address where tanks are located: West End Food Mart 416 S. O'Bannon Street Raymond, IL 62560 Montgomery County Contact: Gerald Wagahoff 217/229-3313 |
|---|---|

Tanks on the Permit

| Tank # | Product | Capacity | Tank Status | Regulated Status |
|--------|--------------------|----------|----------------------|------------------|
| 5 | Gasoline - Regular | 15,000 | Currently in use | Federal |
| 6 | E15 | 8,000 | Installed/Not in Use | Federal |
| 7 | Gasoline - Premium | 7,000 | Currently in use | Federal |

Tank 5 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------------|---|--------|
| Corrosion Protection - Piping | Fiberglass Non-Corrosive | New |
| Corrosion Protection - Tank | Coatings Non-Corrosive | New |
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection | New |
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD | New |
| Leak Detection - Tank | Non-Discriminating Interstitial Monitoring Sensors | New |
| Overfill Prevention Device | Overfill Drop Tube Valve | New |
| Piping | Ball Valves | New |
| Piping | Fiberglass Double Wall Ameron Dualoy 3000/LCX | New |
| Piping | Fiberglass Single Wall Piping Ameron | New |
| Piping | Flex Connector Steel | New |
| Piping | Other Steel Riser | New |
| Piping | Shear Valves | New |
| Piping | Single Wall STP/Tanktop Sump | New |
| Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Spill Containment Device | Double Wall Spill Bucket | New |
| Tank | Composite Double Wall Modern Welding Glasteel II | New |

Tank 6 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------------|---|--------|
| Corrosion Protection - Piping | Fiberglass Non-Corrosive | New |
| Corrosion Protection - Tank | Coatings Non-Corrosive | New |
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection | New |
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD | New |
| Leak Detection - Tank | Non-Discriminating Interstitial Monitoring Sensors | New |
| Overfill Prevention Device | Overfill Drop Tube Valve | New |
| Piping | Ball Valves | New |
| Piping | Fiberglass Double Wall Ameron Dualoy 3000/LCX | New |
| Piping | Fiberglass Single Wall Piping Ameron | New |
| Piping | Flex Connector Steel | New |
| Piping | Other Steel Riser | New |
| Piping | Shear Valves | New |
| Piping | Single Wall STP/Tanktop Sump | New |
| 🔧 Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Spill Containment Device | Double Wall Spill Bucket | New |
| Tank | Composite Double Wall Modern Welding Glasteel II | New |

Tank 7 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------------|---|--------|
| Corrosion Protection - Piping | Fiberglass Non-Corrosive | New |
| Corrosion Protection - Tank | Coatings Non-Corrosive | New |
| Leak Detection - Piping | Electronic Pressurized Line Leak Detection | New |
| Leak Detection - Tank | Automatic Tank Gauging Veeder Root TLS 450 Plus with CSLD | New |
| Leak Detection - Tank | Non-Discriminating Interstitial Monitoring Sensors | New |
| Overfill Prevention Device | Overfill Drop Tube Valve | New |
| Piping | Ball Valves | New |
| Piping | Fiberglass Double Wall Ameron Dualoy 3000/LCX | New |
| Piping | Fiberglass Single Wall Piping Ameron | New |
| Piping | Flex Connector Steel | New |
| Piping | Other Steel Riser | New |
| Piping | Shear Valves | New |
| Piping | Single Wall STP/Tanktop Sump | New |
| 🔧 Leak Detection - Piping | Sump Sensor with positive shutdown | New |
| Spill Containment Device | Double Wall Spill Bucket | New |
| Tank | Composite Double Wall Modern Welding Glasteel II | New |

Dispensers on the Permit

| Dispenser | Action |
|-----------|-----------------|
| 1/2 | Replacing - 1/2 |
| 3/4 | Replacing - 3/4 |

Dispenser 1/2 Equipment

| Equipment Type | Permit Equipment | Action |
|---------------------------|------------------------------------|--------|
| Dispenser | Single Wall UDC Sump | New |
| 🔧 Leak Detection - Piping | Sump Sensor with positive shutdown | New |

Dispenser 3/4 Equipment

| Equipment Type | Permit Equipment | Action |
|-------------------------|------------------------------------|--------|
| Dispenser | Single Wall UDC Sump | New |
| Leak Detection - Piping | Sump Sensor with positive shutdown | New |

General Requirements

USTs shall be installed to safeguard against movement by anchoring in accordance with manufacturer's instructions.

There shall be a minimum of two manufactured slotted or perforated observation wells of at least 4 inches in diameter, installed in each new tank field of tanks larger than 1000 gallons and one well for tanks less than 1000 gallons. A water tight containment shall be installed under all dispensers and at submersible pumps. A hydrostatic test must be performed on all containments. All steel piping for vents, risers, and fills in contact with the ground, backfill, or water shall be dielectrically wrapped or coated. A positive shut off valve shall be installed on pressurized product lines, at the submersibles, or installed at the tank for all suction piping systems. Vent piping is required to be tested from tank to grade level. All steel flex connectors in contact with ground, backfill or water shall have corrosion protection.

Summary of Work

Installing new tanks, piping and equipment as per the permit application. All set backs are met.
Compatibility paperwork to follow

Special Contingencies

NOTES: Vents must meet section 175.440 of our rules. Dispensers must be a full 10' from buildings and property lines.

Amendment Reason #1:

Shifted tanks to allow for proper sloping of tank hole.

Amendment Reason #2:

Product for ID #6 has been changed to E-15

| PERSON, FIRM OR COMPANY PERFORMING WORK: | |
|---|---|
| Total Petroleum Service Company 2421 Washington Road Washington, IL 61571 | Contact Person: Cheri McCoy Phone: 309/694-8224 Email: Tom.Oltman@TotalPetroleum.net Contractor License # IL1079 Exp. 2/8/2026 |

Sincerely,



Daniel Starks