



**Office of the Illinois State Fire Marshal**  
**Division of Petroleum and Chemical Safety**  
1035 Stevenson Drive  
Springfield, IL 62703  
217/785-1020  
www.sfm.illinois.gov  
SFM.DPCS@illinois.gov  
**Amended**

**FOR OFFICE USE ONLY**  
Facility #: 4029144  
Permit #: 00692-2025UPG  
Request Rec'd: 06/04/2025  
Approval Date: 06/04/2025 DS  
Amended Date: 06/21/2025 DS  
Permit Expires: 12/04/2025

**Permit for UPGRADE or REPAIR of Underground Storage Tank(s) and Piping for Petroleum and Hazardous Substances**

Permission to upgrade or repair underground storage tank(s) or piping is hereby granted. Such upgrade or repair must be in complete accordance with acceptable materials as specified in the Federal Register, Part II Environmental Protection Agency, 40 CFR Parts 280 and 281, and also with all sections of 41 Illinois Administrative Code, Parts 174, 175 and 176. The contractor the permit was issued to shall establish a date and time certain to perform the UST activity by scheduling the permitted activity through their UST contractor portal account. All testing forms must be submitted prior to the final being conducted.

**THIS PERMIT IS VALID FOR SIX MONTHS FROM THE APPROVAL DATE.**

<b>OWNER OF TANKS</b> - Corporation, partnership, or other business entity: De Witt County Jail 101 West Washington Street Clinton, IL 62727 Dewitt County Contact: Kevin Kemp 217/935-8818	<b>FACILITY</b> - name and address where tanks are located: De Witt County Jail 101 West Washington Street Clinton, IL 62727 Dewitt County Contact: Kevin Kemp 217/935-8818
---------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

**Tanks on the Permit**

Tank #	Product	Capacity	Tank Status	Regulated Status
1	Diesel Fuel	2,500	Currently in use	Federal

**Tank 1 Equipment**

Equipment Type	Permit Equipment	Action
Leak Detection - Tank	Automatic Tank Gauging Veeder Root TLS 350 Plus with CSLD	Replacing - Leak Detect - Tank - Automatic Tank Gauging Veeder Root TLS 300c

**Summary of Work**

Installing Veeder Root TLS 350 Plus with CSLD tank monitor.

**Special Contingencies**

**Amendment Reason:**

Facility tank monitor system will not upgrade to CSLD. Installing Veeder Root TLS 350 with CSLD.

<b>PERSON, FIRM OR COMPANY PERFORMING WORK:</b>	
Total Petroleum Service Company 2421 Washington Road Washington, IL 61571	Contact Person: Cheri McCoy Phone: 309/694-8224 Email: Tom.Oltman@TotalPetroleum.net Contractor License # IL1079 Exp. 2/8/2026

Sincerely,

Daniel Starks